

RECEIVED

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

SEP 5 1984

PLEASE TYPE OR PRINT IN INK WATER RESOURCES DEPT

MARI... 7780 SS/W-17c Record (for official use only)

(1) OWNER: Well No. 5 SALEM, OREGON Name BirdsEye Div. - General Foods Corp. Address P.O. Box 568 City Woodburn, OR State 97071

(10) LOCATION OF WELL by legal description: County Marion SW 1/4 of Section 17 Township 5S Range 1W, WM. Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address)

(2) TYPE OF WORK (check): New Well [ ] Deepening [ ] Reconditioning [X] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check): Rotary Air [ ] Driven [ ] Domestic [ ] Industrial [X] Municipal [ ] Rotary Mud [ ] Dug [ ] Irrigation [ ] Thermal [ ] Withdrawal [ ] Reinjection [ ] Cable [X] Bored [ ] Piezometric [ ] Grounding [ ] Test [ ]

(11) WATER LEVEL of COMPLETED WELL: Depth at which water was first found 92 ft. Static level 92 ft. below land surface. Date 8/28/84 Artesian pressure lbs. per square inch. Date

(5) CASING INSTALLED: Steel [ ] Plastic [ ] Threaded [ ] Welded [ ] Diam. from ft. to ft. Gauge UNCHANGED

(12) WELL LOG: UNCHANGED Diameter of well below casing ft. Depth of completed well ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

LINER INSTALLED: Steel [X] Plastic [ ] Threaded [ ] Welded [X] 10" Diam. from +1 ft. to 179 ft. Gauge 250

Table with columns: MATERIAL, From, To, SWL. Content: Well was completed May 29, 1963 by R. J. Strasser Drilling Co. It was discovered that the existing 12" casing was badly corroded allowing additional gravel placed between the existing 20" & 12" casing by the owner, to fall inside the 12" casing. The 10" liner was installed to a depth below the lowest anticipated pumping level and has a 1/2" square stock welded circumferentially on the bottom to trap any larger sized rocks between the 12 & 10 inch casings. Six sacks of large granular bentonite were placed between the 12 and 10 inch to also help prevent gravel, rust etc. from entering inside the casing/screen area.

(6) PERFORATIONS: Perforated? [ ] Yes [X] No Size of perforations in. by perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [ ] No Manufacturer's Name Type UNCHANGED Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [ ] No If yes, by whom? gal./min. with ft. drawdown after hrs. UNCHANGED Air test gal./min. with drill stem at ft. hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes [ ] No [X] Well seal—Material used Well sealed from land surface to Diameter of well bore to bottom of seal in. Diameter of well bore below seal UNCHANGED Amount of sealing material sacks [ ] pounds [ ] How was cement grout placed? Was pump installed? Type HP Depth ft. Was a drive shoe used? [ ] Yes [ ] No Plug Size: location ft. Did any strata contain unusable water? [ ] Yes [ ] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [ ] No Size of gravel: Gravel placed from ft. to ft.

Date work started 8/30/84 /completed 8/30/84 Date well drilling machine moved off of well 8/30 19 84

(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Donald J. Davis Date 9-4, 19 84

(bonded) Water Well Constructor Certification: Bond EX490-652 Issued by: American States Ins.CO. (number) (Surety Company Name) On behalf of Stephen J. Schneider (type or print name of Water Well Constructor) This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. [Signed] Stephen J. Schneider (Water Well Constructor) (Dated) 9/4/84

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP\*46866-690

SEI8412