

RECEIVED

OBSERVATION WATER WELL REPORT

MAR 20 1962

1821
5/1W-17N1

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

State Well No. _____
State Permit No. G 1968

62131

(1) OWNER:

Name General Foods Corp.
Address Birds Eye Division Well # 3
Woodburn, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 17 T. 5S R. 1 W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 185 ft. Gage 5/16
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Millknife
Size of perforations 1/4 in. by 2 in.
315 perforations from 155 ft. to 162 ft.
540 perforations from 123 ft. to 135 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Model No. _____
Slot size _____ ft. to _____ ft.
Diam. _____ Slot size _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Mud
Depth of seal 40 ft. Was a packer used? No
Diameter of well bore to bottom of seal 22 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 33 ft. below land surface Date 2/7/62
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 750 gal./min. with 72 ft. drawdown after 3 1/2 hrs.
" 800 " " 82 " 3 "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 15 1/2

Depth drilled 194 ft. Depth of completed well 194 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Sandy brown clay	3	37
Blue sandy clay	37	70
Broken sand	70	90
Blue clay	90	112
Black sand	112	124
Gravel	124	136
Blue clay	136	155
Gravel--Static level 36'2"	155	162
Sticky blue clay	162	168
Sandy blue clay	168	187
Sandy gray clay	187	194

Work started Jan 5 1962 Completed Feb 7 1962
Date well drilling machine moved off of well Feb 12 1962

(13) PUMP:

Manufacturer's Name Jacuzzi
Type: 9 stage Turbine H.P. 100

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)

Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277

[Signed] John Truman Miller
(Water Well Contractor)

Contractor's License No. 277 Date Feb 7, 1962