## - WATER WELL REPORT STATE OF OREGON

193.I

## RECEIVED

State Well No

. 55/1W-18

APR 23 1982

WATER RESOURCES DEPT

State Permit No.	
1	1 - 1
aband	Xover.

	CALLIN, LINE LIN
(1) OWNER:	(10) LOCATION OF WELL:
Name City Of Woodburn	County Marion Driller's well number
Address 270 Montgomery	4 4 Section 18 T. 5 S R. 1 W W.M.
City Woodburn State OR 97071	Tax Lot #_ Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well □ Deepening □ Reconditioning □ Abandon 🕱	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level ft. below land surface. Date
Rotary Air	Artesian pressure lbs. per square inch. Date
Retary Mud   Dug   Irrigation   Test Well   Other     Bored   Thermal: Withdrawal   Reinjection	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel  Plastic	Depth drilled ft. Depth of completed well ft.
(5) CASING INSTALLED: Steel   Plastic   Threaded   Welded	Formation: Describe color, texture, grain size and structure of materials; and show
ft. toft. Gauge	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
" Diam. from	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. Gauge	Well was pressure grouted
(6) PERFORATIONS: Perforated?   ▼ Yes □ No	with bentonite and cement
Type of perforator used Mill Knife	plugs were placed at 111 ft.
Size of perforations 3/8 in. by 3 in.	to 118 ft. and 12 ft. to
700 perforations from30 ft. to116 ft.	25 ft.
ft. to ft.	Well was abandoned by special
perforations fromft. toft.	structures Standard Approval
(7) SCREENS: Well screen installed?   Yes X No	Dated 4-6-82.
Manufacturer's Name	
Type Model No	5 AP (II)
Diam. Slot SizeSet from ft. to	The second secon
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made? 🗆 Yes 🗶 No 🏗 yes, by whom?	
rield: gal/min. with ft. drawdown after hrs.	
Air test gal/min with drill stem at ft. hrs.	3 8 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4
Bailer test gal/min with ft. drawdown after hrs.	
esian flow g.p.m.	
remperature of water Depth arisian flow encountered ft.	Work started 11-20 19.82 Completed 11-21-86x 19.82
(9) CONSTRUCTION: Special standards: Yes X No □	Work started 4-20 19.82 Completed 4-21-86x 19.82  Date well drilling machine moved off of well 4-21 19.82
Well seal—Material usedCement grout and bentonite	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Date 4-22., 1982.
Number of sacks of cement used in well seg sacks	Drilling Machine Operator's License No883.
How was cement grout placed?	
Total State of the	Water Well Contractor's Certification:
TID D. I	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was pump installed?	Name Donnelly Drilling Co.
Was a drive shoe used? ☐ Yes ☐ No  Did any strata contain unusable water? ☐ Yes ☐ No	(Person, firm or corporation) (Type or print)
Type of Water? depth of sata	Address P. Box 5, Amora, 9r. 97002
Method of sealing strata off	[Signed] two termell
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Marketor)  Contractor's License No. 806 Date 1-22 , 19.82
Gravel placed from	19.02