

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR 1 1965 well #3 G 5277

State Well No. 3/2W-29ca State Permit No.

(1) OWNER:

Name City of Newberg Address Newberg, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 1/4 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner Sec. 29 3S 2W

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X] 18" Diam. from 0 ft. to 103 ft. Gage 375

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Mills Knife Size of perforations 3/8 in. by 2 1/2 in. 520 perforations from 55 ft. to 68 ft. 560 perforations from 77 ft. to 91 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 34 ft. Was a packer used? No Diameter of well bore to bottom of seal 24 in. Were any loose strata cemented off? No Depth of drive shoe used? Yes [X] No Well gravel packed? Yes [] No [X] No Size of gravel: Placed from ft. to ft. Strata contain unusable water? Yes [] No [X] No

GR LEVELS:

37 ft. below land surface Date 5/29/64 lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Driller Yield: 1800 gal./min. with 9 ft. drawdown after 12 hrs.

(12) WELL LOG:

Diameter of well below casing 18" Depth drilled 101 ft. Depth of completed well 101 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top Soil, Sandy loam, brown, Coarse sand, brown, Brown silty sand w/water, Grey sand, Pea Gravel, Coarse gravel & sand, Cemented gravel, Loose gravel, water bearing, Grey clay.

Work started 5/12 1964. Completed 5/29 19 64 Date well drilling machine moved off of well 6/1 19 64

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Janssen Drilling Company (Person, firm or corporation) (Type or print)

Address 21075 S. W. Tualatin Valley Hwy., Aloha, Oregon

Drilling Machine Operator's License No. 274 [Signed] Edward M. Janssen (Water Well Contractor)

Contractor's License No. 79 Date 6/2/1964