46

Application No. G-13498

MARI 18139

8S/3W/32

RECEIVED

AUG 20 1993

WATER RESOURCES DEPT
SALEM, OREGON

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

Permit No.

PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:

Name [illegible]

Address

City Salem State ORE

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☐ Driven ☐

Rotary Mud ☐ Dug ☐

Cable ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐

Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐

Other: Piezometric ☐ Grounding ☐ Test ☐

(5) CASING INSTALLED: Steel ☒ Plastic ☐ Threaded ☐ Welded ☒

6" Diam. from +1 ft. to 50 ft. Gauge .250

Diam. from ft. to ft. Gauge

LINER INSTALLED: Steel ☐ Plastic ☐ Threaded ☐ Welded ☐

Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" "

Air test gal./min. with drill stem at ft. hrs.

Bailer test [illegible] gal./min. with 10 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☒

Well seal—Material used Cement Grout

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Amount of sealing material 12 sacks ☒ pounds ☐

How was cement grout placed? Poured Through

[illegible] Pipe

Was pump installed? Type HP Depth ft.

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County MARION ¼ ¼ of Section 32 of

Township 8S (Township is North or South), Range 3W (Range is East or West), WM.

Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 120 ft.

Static level 90 ft. below land surface. Date 8-18

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
[illegible]	0	2	
Clay	2	25	
[illegible]	25	140	90

Date work started 8-16- /completed 8-18-

Date well drilling machine moved off of well 8-17 1986

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Tom [illegible] Date 8-20, 1986

(bonded) Water Well Constructor Certification:

Bond (number) Issued by: (Surety Company Name)

On behalf of (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) (Water Well Constructor)

(Dated)

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310

within 30 days from the date of well completion

SP*46866-690