

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97301
within 30 days from the date
of well completion.

1875
MARI... WATER WELL REPORT

RECEIVED
APR 27 1967

STATE ENGINEER
STATE OF OREGON
(Please type or print)

State Well No. 5/1w-19
State Permit No.

(1) OWNER:

Name FRED GESCHWILL
Address ROUTE # 2 BOX 302A
WOODBURN, OREGON 97071

(2) LOCATION OF WELL:

County MARION Driller's well number 36
1/4 Section 19, 8, 30 T. 5S R. I WEST W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 182 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used MILLS
Size of perforations 3/8 in. by 3 1/2 in.
130 perforations from 115 ft. to 128 ft.
260 perforations from 167 ft. to 180 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal PUDDLE CLAY
Depth of seal 20 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 16 ft. below land surface Date APRIL 25, 1967
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STETTLER'S
Yield: 350 gal./min. with 74 ft. drawdown after 4 hrs.
" 400 " 84 " 4 "
" 500 " 94 " 4 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 182 ft. Depth of completed well 182 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
BROWN CLAY	3	30
BROWN SAND	30	37
BLUE CLAY	37	55
GREY SAND	55	62
BLUE CLAY	62	75
BLACK SAND	75	80
BLUE CLAY	80	105
BLACK SAND	105	110
BROWN SAND	110	115
GRAVEL	115	128
BLUE SHALE	128	130
BLUE CLAY	130	145
BROWN CLAY	145	155
BLUE CLAY	155	167
SAND & GRAVEL	167	182

Work started MARCH 8 67 Completed APRIL 25 19 67

Date well drilling machine moved off of well MARCH 22 19 67

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. E. TERRELL
(Person, firm or corporation) (Type or print)

Address RT # 1, BOX 57, GERVAIS, OREGON

Drilling Machine Operator's License No. 179

[Signed] Mrs. Jona Gale Terrell
(Water Well Contractor)

Contractor's License No. 460 Date APRIL 25, 19 67