

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT APR 10 1964 STATE OF OREGON (Please type or print)

MARI. 1889

State Well No. 5 8/1W-19A State Permit No. G-2805

(1) OWNER:

Name BIRDS EYE DIVISION OF GENERAL FOODS CORP. Address WOODBURN ORE.

(2) LOCATION OF WELL: Marion County CLATSOP Driller's well number 4168

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded 10" Diam. from 0 ft. to 145 ft. Gage 279 8" Diam. from 154 ft. to 167 ft. Gage 277

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used Size of perforations in. by in. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No Manufacturer's Name JOHNSON Type STAINLESS STEEL Model No. Diam. 10 Slot size 80 Set from 145 ft. to 154 ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT Depth of seal 40 ft. Was a packer used? Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? SURFACE Depth of strata 12 FEET Method of sealing strata off CASING AND CEMENT

(10) WATER LEVELS:

Static level 30 ft. below land surface Date 4/8/64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? Yes No If yes, by whom? R. STRASSER DRILLING CO Yield: 380 gal./min. with 80 ft. drawdown after 6 hrs. " 260 " 48 " 1 " " 215 " 38 " " " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 59° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Depth drilled 167 ft. Depth of completed well 167 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
CLAY	2	6
SILT WITH CLAY BINDER	6	25
SAND WITH SILT	25	37
SILT AND CLAY	37	71
PACKED SAND	71	79
SANDY CLAY	79	95
CLAY	95	117
CEMENTED GRAVEL	117	125
BLUE CLAY	125	136
SANDY SILT	136	145
SAND AND GRAVEL (WATER)	145	153
BLUE SAND, CLAY BINDER	153	167

Work started MAR 19 1964 Completed APR. 10 1964 Date well drilling machine moved off of well APR. 10 1964

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. J. STRASSER DRILLING CO (Person, firm or corporation) (Type or print) Address 8110 SE SUNSET LANE PORT. ORE Drilling Machine Operator's License No. 58 [Signed] Robert J. Strasser (Water Well Contractor) Contractor's License No. 10 Date APR. 14, 1964