

RECEIVED

MAR 19 1966

NOTICE TO WATER WELL CONTRACTOR JUL 18 1966
The original and first copy of this report are to be filed with the STATE ENGINEER WATER WELL REPORT
STATE ENGINEER, SALEM, OREGON 97310 STATE OF OREGON
within 30 days from the date of well completion. (Please type or print)

State Well No. 5/10-19 @
State Permit No. G-3634

(1) OWNER:

Name MRS. BETIE DRYDEN
Address RT. 2 BOX 300 WOODBURN, OREGON.

(2) LOCATION OF WELL:

County MARION Driller's well number II53
1/4 Section 19 - 30 T 5 R. I W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from TOP ft. to 197 ft. Gage 250
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 2 in. by 3/8 in.
60 perforations from 123 ft. to 126 ft.
460 perforations from 175 ft. to 197 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUTTLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 37 ft. below land surface Date 6/29/66
Artesian pressure lbs per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 650 gal./min. with 67 ft. drawdown after 6 hrs.
" 550 " " 58 " " 6 "
" 450 " " 48 " " 6 "
~~370~~ gal./min. with 44 ft. drawdown after 6 hrs.
~~330~~ g.p.m. ~~37~~ FT. D.D. 6 H
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 197 ft. Depth of completed well 197 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	5	3
YELLOW CLAY	3	18
YELLOW SANDY SILT	18	40
BLUE SANDY SHALE	40	60
BLACK SANDY SHALE	60	80
BLACK SHALE STICKY	80	100
BROWN STICKY SHALE	100	115
BROWN SAND	115	120
SMALL GRAVEL	120	122
BLACK SAND SCATTERED GRAVEL	122	135
SAND & SHALE MIXED	135	145
STICKY SHALE	145	160
SANDY BLUE SHALE	160	170
BLACK SAND & GRAVEL	170	197

Work started JUNE 13 1966 Completed JULY 29 1966
Date well drilling machine moved off of well JUNE 29 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON.

Drilling Machine Operator's License No. 74

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date JUNE 29 1966