

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

MAR 19 1965

State Well No. 5/1w-21

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name John A Sloemaker  
Address Rte 2 Box 50  
Woodburn, Oregon

(2) LOCATION OF WELL:

County Marian Driller's well number \_\_\_\_\_  
1/4 Section 21 T. 5S R. 1W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded

8" Diam. from 0 ft. to 101 ft. Gage 1/4"  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used Millknife  
Size of perforations 3/8 in. by 2 in.  
78 perforations from 89 ft. to 95 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud  
Depth of seal 20 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusuable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 24'6" ft. below land surface Date 7/19/65  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
Yield: 120 gal./min. with 80 ft. drawdown after 4 hrs.

" " " "  
" " " "  
" " " "  
" " " "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 112 ft. Depth of completed well 112 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	43
Blue sandy clay	43	66
Brown clay	66	80
Black sand	80	88
Broken gravel	88	95
Blue clay	95	108
Broken sand and gravel	108	112

RECEIVED  
AUG 16 1965  
STATE ENGINEER  
SALEM OREGON

Work started July 13 1965. Completed July 19 1965  
Date well drilling machine moved off of well July 19 1965

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller  
(Person, firm or corporation) (Type or print)  
Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277-26

[Signed] John Truman Miller  
(Water Well Contractor)

Contractor's License No. 26 Date August 5, 1965