

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

MARI. 2025

WATER WELL REPORT

RECEIVED

OCT 17 1973

State Well No. 55/1W-27

ba

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Permit No.

(Do not write above this line)

Card in Sept 1 73

(1) OWNER:

Name Max Abel Wendel Patch
Address Rt 2 Box 54 Woodburn Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 140 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/2 in.
4.05 perforations from 110 ft. to 137 ft.
4.0 perforations from 84 ft. to 88 ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 140 gal./min. with 57 ft. drawdown after 7 hrs.

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 84 ft.
Diameter of well bore to bottom of seal 11" X in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 10 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
NE 1/4 NW 1/4 Section 27 T. 5 S R. 1 W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
Static level 43 ft. below land surface. Date 9-14-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Redish Brown clay	2	21	
Silty Brown clay	21	26	
Redish Brown clay	26	46	
Cement Gravel	46	64	
Dark silt	64	85	
Brown gravel	85	87	
Brown clay	87	89	
Black clay	89	108	
Cement Gravel	108	128	
Gravel	128	137	
Dark clay	137	140	

Work started 9-10 1973 Completed 9-20 1973
Date well drilling machine moved off of well 9 21 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John W Beck Date 9-21, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 437

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name S W Beck well drilling
(Person, firm or corporation) (Type or print)

Address 24437 S. 24th Ave Dr. Canby Ore

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. 449 Date 9-21-1973

(USE ADDITIONAL SHEETS IF NECESSARY)