

RECEIVED

WATER WELL REPORT  
STATE OF OREGON

MARI..2029

51W-27H(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JUL 27 1959

State Well No.

State Permit No.

6-774

(1) OWNER: SALEM, OREGON  
Name: Ladonne Norton  
Address: Box 64  
Woodburn Ave

(2) LOCATION OF WELL:  
County: Marion Owner's number, if any—  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:  
6" Diam. from 117 ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:  
Type of perforator used \_\_\_\_\_  
SIZE of perforations in. by in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 40 ft. below and surface Date July 25  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:  
[Signed] Ladonne Norton Date July 2, 1959  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 170 gal./min. with 22 ft. drawdown after 20 hrs.  
" " " " "  
" " " " "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 6 inches.  
Depth drilled 123 ft. Depth of completed well 122 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil & sand	0	23'
gray sand	23	50
sand clay	50	59
sand gravel	59	75
sand clay	75	98
sand	98	105
sand gravel	105	110
gravel hard pan	110	115
sand gravel	115	123

Work started April 31 1959 Completed July 25 1959

(13) PUMP:  
Manufacturer's Name \_\_\_\_\_  
Type: Garage H.P. 3

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME \_\_\_\_\_ (Person, firm, or corporation) (Type or print)  
Address \_\_\_\_\_  
Driller's well number \_\_\_\_\_  
[Signed] \_\_\_\_\_ (Well Driller)  
License No. \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_\_\_