NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

STATE OF OREGON

WATER WELL REPORTED TO THE WATER WELL REPORT OF OREGON WITH THE RESOURCES DEPARTMENT, 17 1978

STATE OF OREGON WITH CARE RESOURCES DEPTPlease type or print) of well completion. SALEM, OREGON (Do not write above this line)



(1) OWNER: G-11403	(10) LOCATION OF WELL:
Name Salem Nursery Inc.	County Marion Driller's well number 2174
Address 12839 McKee School Rd.	34 34 Section 28 T. 5S R. 1W W.M.
Woodburn, Oregon 97071	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well M Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 43 ft.
Rotary Driven Domestic Industrial Municipal	Static level 25 ft. below land surface. Date $9/1/78$
Dug Bored Irrigation \(\) Test Well Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded To Welded X 10 Diam from top ft. to 207 ft. Gage .250	(12) WELL LOG: Diameter of well below casing 10"
"Diam. fromft. toft. Gage	Depth drilled 225 ft. Depth of completed well 225 ft.
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials;
	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? X Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Mills Knife	MATERIAL From To SWL
Size of perforations 3/8 in. by $2\frac{1}{4}$ in.	Topsoil 0 1
5/1	Yellow Clay 1 35
70 perforations from 47 ft. to 34 ft. 590 perforations from 72 ft. to 120 ft.	Blue Clay 35 43
perforations from ft. to ft.	Brown Sand and Gravel 43 50
	Black Sand and Gravel 50 54
(7) SCREENS: Well screen installed? Yes X No	Yellow Clay 54 60
Manufacturer's Name	Brown Sand 60 65
Type Model No.	Brown Sand and Gravel 65 120
Diam. Slot size Set from ft. to ft.	Blue Clay 120 225
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? X Yes □ No If yes, by whom? driller	
Vield: 250 gal./min. with 95 ft. drawdown after 3 hrs.	
" " "	
" - " "	
Bailer test gal./min. with ft. drawdown after hrs.	.+
A Dec	4-
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started 7/17/78 19 Completed 9/1/78 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well 9/1/78 19
Well seal—Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal 12 in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	1
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)
How was cement grout placed? policed in from the top	Drilling Machine Operator's License No. 536
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
77	true to the best of my knowledge and belief.
Was a drive shoe used? N Yes No Plugs Size: location ft.	
Was a drive shoe used? X Yes \(\Pi\) No Plugs \(\frac{1}{2}\) Size: location	Name Willamette Drilling Co. (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? No Type of water? depth astrata	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? No Type of water? depth dstrata Method of sealing strata off	(Person, firm or corporation) Address 1450 Barnick Rd. NE Salem, OR 97303 [Signed]
Did any strata contain unusable water? No Type of water? depth astrata	Address 1450 Barnick Rd. NE Salem, OR 97300