NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be

WATER WELL REPORT

State Well No. 5/16-3

filed with the

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 77310

within 30 days from the date
of well completion.

of well completion.	above this line) State Permit N	O		
(1) OWNER: SALE OREGON	(11) LOCATION OF WELL:			
Name Veronica Kuschnick Hartman	County Marion Driller's well n	umber .	1298	
Address Second St. Silverton, Oregon	¼ ¼ Section 3] -32. 5		1W	W.M.
	Bearing and distance from section or subdivision		-1. ¥¥	
(2) TYPE OF WORK (check):	Douring and distance from South St. San arvins			
New Well Deepening Reconditioning Abandon				
f abandonment, describe material and procedure in Item 12.			•	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well		•	
Rotary Driven Domestic Industrial Municipal	Depth drilled 174 ft. Depth of comp.		_	ft.
Oug 🗌 Bored 🗎 Irrigation 🔀 Test Well 🗌 Other 📋				
CASING INSTALLED: Threaded Welded \text{\foint Melded \foint Gage 250}	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.			
ft. to ft. Gage	MATERIAL -	From	То	SWL
ft. Diam. from ft. to ft. Gage	Top Soil	0	3	<u> </u>
PERFORATIONS: Perforated? X Yes \(\square\) No.	Yellow Clay	3	55	
Type of perforator used Mills	Blue Clay	55	65	
Size of perforations 1/4 in. by 23 in.	Black Sand	65	75	26
7.00	Blue Clay	75	80	
204 perforations from 157 ft. to 174 ft.	Gray Clay	80	105	
perforations from ft. to ft.	Black Sand	105	110	26
perforations from ft. to ft.	Gray Clay	110	125	
perforations fromft. toft.	Black Sand	125	135	
(E) COPETING	Gravel Gray Shale	135	150	23
(7) SCREENS: Well screen installed? Yes X No	Gravel	150 157	157 174	97
Manufacturer's Name	MI II WILL	1 1 1	1/4	23
Type Model No Diam Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
		<u> </u>		
(8) WATER LEVEL: Completed well.	Woll herelod at	-		
Static level 23 ft. below land surface Date 4-8-68	At. Jorgian	<u> </u>		-
lbs. per_square inch Date	C/ro,		<u> </u>	
(9) WELL TESTS: Drawdown is amount water level is				
lowered below static level Was a pump test made? X Yes \(\square\) No If yes, by whom? Driller		 	3.	
	Work started 3-21-68 19 Complet	ed 48	-68	19
14: 400 gal./min. with 16 ft. drawdown after 1 hrs.	Work started 3-21-68 19 Completed 4-8-68 19 Date well drilling machine moved off of well 4-9-68 19			
		4-9	-68	10
<u> </u>	Drilling Machine Operator's Certification: This well was constructed under my d			
Statics Yest 700 gal./min. with 26 ft. drawdown after 1 hrs.	rials used and information reported above	rect sup ve are t	rue to	. mate- my best
Artesian flow g.p.m. Date	knowledge and belief.			
Temperature of water 55Was a chemical analysis made? 🗆 Yes 🛣 No	[Signed] Windle 21. Motor (Drilling Machine Operator)	Date4	8.=68	., 19
(10) CONSTRUCTION:				
Well seal-Material use Drill cuttings puddle clay	Drilling Machine Operator's License No			
Depth of seal 20 ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal = 14 in.	This well was drilled under my jurisd	iction ar	nd this r	eport is
Were any loose strata cemented off? 🖂 Yes 🍒 No 🛮 Depth	true to the best of my knowledge and belief.			
Was a drive shoe used? ★ Yes □ No	NAME WILLAMETTE DRILLING COMPANY (Person, firm or corporation) (Type or print)			
old any strata contain unusable water? Yes X No				
pe of water? depth of strata	Address 7641 35th Ave. NE Salem, Oregon			
hod of sealing strata off	[Signed] Sull (). Be	LOR)	
well gravel packed? Yes X No Size of gravel:	(Water Well Contract	tor)		
placed from ft. to ft.	Contractor's License No. 2. Date 4:	-9-68		19