

RECEIVED

2162
MAR 11 1987

59/1W-3466

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

MAR 30 1987

(1) OWNER: **WATER RESOURCES DEPT**
Name KENNETH FESSLER Owner's Well Number _____
Address 12666 MONITOR MCKEE RD NE SALEM, OREGON
City WOODBURN State OR Zip 97071

(9) LOCATION OF WELL by legal description:
County MARION Latitude _____ Longitude _____
Township 5 S N or S, Range 1 W E or W, WM.
Section 34 NW 1/4 NW 1/4
Tax Lot _____ Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) _____

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(10) STATIC WATER LEVEL:
42' ft. below land surface. Date MARCH 16
Artesian pressure _____ lb. per square inch. Date _____

(5) BORE HOLE CONSTRUCTION:
Depth of Completed Well 240 ft.
Special Standards date of approval _____

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
12	1	20	CEMENT	1	204	11 SACKS
8	20	240				

How was seal placed? Method A B C D E
 Other TREMBLE
Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from 235 ft. to 240 ft. Size of gravel 3/8 MINUS

(11) WELL LOG: Ground elevation _____

Material	From	To	WB?	SWL
TEPSCIL	1	4		
CLAY BROWN	4	25		
CLAY GREY	25	34		
Cemented GRAVEL	34	61	✓	3
CLAY GREY	61	65		
Cemented GRAVEL	65	85		
CLAY GREY SILTY	85	100		
CLAY & BLACK SAND (wood)	100	105	✓	
CLAY BLUE	105	170		
CLAY DK GREEN	170	204		
SAND	204	206	✓	
CLAY GREY	206	235		
SAND & WOOD	235	240		

(6) CASING/LINER:
Diameter From To Gauge Steel Plastic Welded Threaded
Casing: 8 0 235 250
Liner: _____
Final location of shoe(s) 235

Date started FEB 25, 1987 Completed MAR 16, 1987

(7) PERFORATIONS/SCREENS:
 Perforations Method STAR
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
65	85	3/8 X 1/2	200ea			<input checked="" type="checkbox"/>	<input type="checkbox"/>

(unbonded) Water Well Constructor Certification:
I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
Signed _____ Date _____

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing
Yield gal/min Pumping level Drill stem at Time
65 90 _____ 24
1 hr

(bonded) Water Well Constructor Certification:
I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.
Signed Richard Beck Date MARCH 16, 1987
Company Beck Well Drilling Col Job No. _____

Temperature of water _____ Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____