

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
STATE ENGINEER
 SALEM, OREGON
 MAY 23 1968
 (Please type or print)
 (Do not write above this line)

MARI. 2/86

State Well No. 5/100-35 D

State Permit No.

G-4463

(1) OWNER:

Name CHARLES BOCHSLER
 Address RT 1 MT. ANGEL, OREG

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 1 1/8" Diam. from 0 ft. to 20 ft. Gage 250
 1" Diam. from 0 ft. to 215 ft. Gage 250

(6) PERFORATIONS:

Perforated? Yes No.
 Type of perforator used FACTORY & TORCH
 Size of perforations 3/16 in. by 3 in.
640 perforations from 195 ft. to 215 ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name JOHNSON
 Type IRRIGATOR Model No. #100
 Diam. 8 Slot size 100 Set from 75 ft. to 95 ft.
 Diam. Slot size Set from 755 ft. to 115 ft.

(8) WATER LEVEL: Completed well.

Static level 30 ft. below land surface Date 5/20
 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 400 gal./min. with 145 ft. drawdown after 6 hrs.
350 " 125 " 6 "
300 " 90 " 6 "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT
 Depth of seal 20 ft.
 Diameter of well bore to bottom of seal 22 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
16" HOPE TO 215
 Was well gravel packed? Yes No Size of gravel: 3/8 - 1/4
 Gravel placed from 0 ft. to 215 ft.

(11) LOCATION OF WELL:

County MARION Driller's well number
 1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner
approx. 975 ft. S. & 300 ft. N.W. corner
of section 35, T.5 S., R.1 W.

(12) WELL LOG:

TEST NOTE
 Diameter of well below casing 8"
 Depth drilled 240 ft. Depth of completed well 215 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL BRN	0	2	
CLAY BRN	2	30	
CLAY GREY	30	44	
SAND LG-GRNLL BRN, H. B	44	88	
CLAY GREY	88	155	
COURSE SAND BLK	155	170	
CLAY GREY	170	192	
CLAY SANDY GREY	192	215	H.B.
CLAY GREY	215	240	

MOVED OFF & WAITED FOR SCREEN
STARTED AGAIN 5/13

Work started 5/3 1968 Completed 5/20 1968
 Date well drilling machine moved off of well 5/21 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C.E. Stadel Date 5/20, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME K. STADEL & SONS
 (Person, firm or corporation) (Type or print)

Address RT 3 BOX 169 SILVERTON

[Signed] Carl R. Stadel
 (Water Well Contractor)

Contractor's License No. 296 Date 5/20, 1968