NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the AUG 29 1967

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date CONTRACTOR
of well completion.

WATER WELL REPORT ARI

19.....

of well completion.	State Permit N	o	······	
(1) OWNER: Name Wurdinger	(11) LOCATION OF WELL:  Kerion  County  Driller's well number			
Address Rt 1 Box 258 Woodburn, Oreg.	¼ ¼ Section T. R. W.M			
	Bearing and distance from section or subdivision	n corner		
(2) TYPE OF WORK (check):  New Well Deepening Reconditioning Abandon If abandonment, describe material and procedure in Item 12.	800 ft S & 400 ft W of N T.5. S,R 2 W.		or se	c 1
(3) TYPE OF WELL: (4) PROPOSED USE (check):  Rotary	Depth drilled ft. Depth of compl	leted well	ີ່ 148 <del>ກໄນຂ</del>	f
CASING INSTALLED: Threaded   Welded   O	and show thickness and nature of each stratu with at least one entry for each change of form in position of Static Water Level as drilling pro-	m and ac nation. Re oceeds. N	quifer per eport each ote drilli	netrated h chang ng rates
" Diam. from ft. to ft. Gage	MATERIAL TO THE TANK	From	То	SWL
DEDEOD A MIONG	Top soil brn	0	1	
PERFORATIONS: Perforated? Yes   No.	Clay brn. Fine sand brn	21	21 36	_
ype of perforator used torch	Clay brn	36	69	
Size of perforations 1/8 in. by 12 in.	Med. sand some fine bl.		<u> </u>	-
perforations from ft. to ft.	gravel W.B.	69	105	
400 perforations from 74 ft. to 154 ft.	Coursesand gravel blk	- 1	127	
perforations from ft. to ft.	Clay brn	127	139	
perforations from	Course sand small			
perforations from ft. to ft.	gravel W.B.	139	154	
Manufacturer's Name         Model No.           Type         Model No.           Diam.         Slot size         Set from         ft. to         ft.           Diam.         Slot size         Set from         ft. to         ft.				
(8) WATER LEVEL: Completed well.  Steric level 25 ft. below land surface Date 5/8/67				
sian pressure lbs. per square inch Date				
(9) WELL TESTS: Drawdown is amount water level is lowered below static level  Was a pump test made? Yes \( \subseteq \) No If yes, by whom! Driller				
. 500	Work started L/27 /67 1967 Complete	ed 5/8	<del></del>	167
gal./min. with ft. drawdown after hrs.	Date well drilling machine moved off of well	5/8		1:67
" " " "				
Bailer test gal./min. with ft. drawdown after hrs.	Drilling Machine Operator's Certification: This well was constructed under my di	rect supe	rvision.	Mate-
Anti-land	rials used and information reported above knowledge and belief.	e are tr	ue to n	ny best
Temperature of water Was a chemical analysis made?  Was a chemical analysis made?  No		Date 7./	/12	1967
(10) CONSTRUCTION: cement	Drilling Machine Operator's License No	84		
Well seal—Material used				
Diameter of well bore to bottom of seel 28	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal	This well was drilled under my jurisdi true to the best of my knowledge and belie Stadeli & Sons	ction and	d this re	eport is
Was a drive shoe used?   Yes No	(Person, firm or corporation)	(Туре	or print)	
Did any strata contain unusable water?   Yes No	Address Box 169, Silverto	n,Ore	g.	
Type of water? depth of strata	1 0 0 1		••••••	
Method of sealing strata off	[Signed] Jaul J. Stade	li		
Was well gravel packed? Yes No Size of gravel: 3/8/4	(Water Well Contrac	(12)		67
Gravel placed from	Contractor's License No. 296 Date	, ±~	,	19