WATER WELL REPORT
STATE OF OREGON

MAR1.2221

RECEIVED
JUN 28 1982
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 4S/1W-2ca
State Permit No.
Reconditioning

(1) OWNER:
Name: Shephard Azaleas
Address: 23050 N.E. Boones Ferry Rd.
City: Aurora State: OR. 97002

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐
Thermal: ☐ Withdrawal ☐ Reinjection ☐

CASING INSTALLED:
Steel ☒ Threaded ☐ Plastic ☐ Welded ☐
8" Diam. from +1 ft. to 207 ft. Gauge .250
7" Diam. from 202 ft. to 208 ft. Gauge .188

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☒ Yes ☐ No
Manufacturer's Name: Johnson
Type: Stainless Model No.
Diam. 7½ Slot Size 80 Set from 213 ft. to 220 ft.
Diam. 7½ Slot Size 30 Set from 208 ft. to 213 ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " "
Air test 200 gal./min. with drill stem at 200 ft. 8 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used: Cement 5% Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8in.
Number of sacks of cement used in well seal XX 19 sacks
How was cement grout placed? pumped
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
N.E. ¼ S.W. ¼ Section 2 T. 4 S. R. 1W. W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 23050 N.E. Boones Ferry Rd. Aurora, OR. 97002

(11) WATER LEVEL: Completed well.
Depth at which water was first found unknown ft.
Static level 79 ft. below land surface. Date 6-25-82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8"
Depth drilled 220 ft. Depth of completed well 200 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay	136	182	
Sand	182	197	
Gravel & Sand	197	222	79

Work started 6-10 19 82 Completed 6-25 19 82
Date well drilling machine moved off of well 6-25 19 82

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] David Donnelly (Drilling Machine Operator) Date 6-26., 1982
Drilling Machine Operator's License No. 883

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Donnelly Drilling Co. (Person, firm or corporation) (Type or print)
Address P.O. Box 5, Aurora, OR. 97002
[Signed] David Donnelly (Water Well Contractor)
Contractor's License No. 806 Date 6-26, 1982

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690