

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

**RECEIVED**

MAR 23 1965

JUL 21 1965 WATER WELL REPORT

State Well No. 5/2w-3 P(1)  
 State Permit No. \_\_\_\_\_

STATE ENGINEER, SALEM, OREGON  
 within 30 days from the date of well completion.  
 STATE ENGINEER (Please type or print)  
 SALEM OREGON G-3559

(1) OWNER:

Name NORMAN WILSON  
 Address RT. 1 BOX 349  
HUBBARD, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I054  
 1/4 Section 3-4 T. 5 S R. 2W W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 Rotary  Cable  Dug  Driven  Jetted  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded  Welded   
12 " Diam. from TOP ft. to 140 ft. Gage 250  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used MILLS  
 Size of perforations 1/2 in. by 2 1/2 in.  
256 perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
120 perforations from 120 ft. to 135 ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Type \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY  
 Depth of seal 20 ft. Was a packer used? \_\_\_\_\_  
 Diameter of well bore to bottom of seal 14 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 7/12/65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? DRILLER  
 Yield: 500 gal./min. with 15 ft. drawdown after 29 hrs.  
 " 600 " " 24 " 29 "  
 " 750 " " 28 " 29 "  
 Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow g.p.m. Date \_\_\_\_\_  
 Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing \_\_\_\_\_  
 Depth drilled I40 ft. Depth of completed well I40 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	5
CLAY	5	25
SAND	25	30
CLAY	30	58
SAND	58	65
CLAY	65	65
SAND	85	95
CLAY	95	105
SAND	105	120
GRAVEL	120	135
SAND	135	140

Work started JULY 3 1965 Completed JULY 12 1965  
 Date well drilling machine moved off of well JULY 12 1965

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO  
 (Person, firm or corporation) (Type or print)  
 Address RT. 2 BOX 276 SALEM, OREGON  
 Drilling Machine Operator's License No. 179  
 [Signed] Emil O. Beier  
 (Water Well Contractor)  
 Contractor's License No. 2 Date JULY 12 1965