

MARI. 2315

RECEIVED
AUG 10 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER (Type or print)
SALEM, OREGON

G-3647

State Well No. 5/2w-3 R
State Permit No. _____

(1) OWNER:

Name Horst P Raustein
Address Rte Box 471
Woodburn, Oregon

(2) LOCATION OF WELL:

County Marian Driller's well number _____
1/4 Section 3 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug
Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
8 " Diam. from 0 ft. to 130 ft. Gage 1/4"
" Diam. from _____ ft. to _____ ft. Gage _____"
" Diam. from _____ ft. to _____ ft. Gage _____"

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Millknife
Size of perforations 3/8 in. by 3 in.
56 perforations from 125 ft. to 127'6" ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud
Depth of seal 20 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 31 ft. below land surface Date 8/9/66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 120 gal./min. with 40 ft. drawdown after 4 hrs.
" 170 " " 69 " 4 "
" " " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 130 ft. Depth of completed well 130 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	3
Brown sandy clay	3	19
Blue sandy clay	19	64
Grey clay	64	81
Broken sand and gravel	81	102
Clay	102	103
Sand	103	106'6"
Broken gravel	106'6"	118
Sand	118	121
Gravel	121	130

Work started August 3 1966 Completed August 9 1966
Date well drilling machine moved off of well August 9 1966

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller (Type or print)
Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 26

[Signed] John T. Miller (Water Well Contractor)

Contractor's License No. 277 Date August 9 1966