

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED JUN - 7 1963 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR 23 1960 2340
G 5778

7B(1)
State Well No. 5120-60
State Permit No.

(1) OWNER:

Name Philip Wolf, Jr.
Address Rt. 1, Box 295, Gervais, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 Section 6 or 7 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner
app 2500 feet West of other well

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
18" Diam. from 0 ft. to 20 ft. Gage .250
12" Diam. from 0 ft. to 156'8" ft. Gage .250

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used torch
Size of perforations 5/16 in. by 8 in.
96 perforations from 68'8" ft. to 76'8" ft.
660 perforations from 96'8" ft. to 151'8" ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
in. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Drilled 24" hole
Well seal—Material used in seal concrete
Depth of seal 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4 - 1/2
Gravel placed from 0 ft. to 156 ft.
Did any strata contain unusable water? Yes No
Type of water Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 5-8-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 1700 gal./min. with 92 ft. drawdown after 6 hrs.
" 1500 " 84 " 6 1/2 "
" 1200 " 79 " 7 "
Bailer test gal./min. with 73 ft. drawdown after 8 hrs.
Artesian flow a.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 151'8" ft. Depth of completed well 154 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	3
Brown clay	3	14
Brown sandy clay	14	19
Grey clay	19	35
Hard grey clay	35	37
Grey clay	37	56
Blue clay	56	64
Black sand	64	72
Brown clay	72	73
Milk colored clay (white)	73	75
Chocolate clay	75	97
Soft brown clay	97	100
Brown clay & sand layer	100	106
Green sand	106	108
Blue clay	108	114
Sand & Brown clay layers	114	120
Light colored clay (white)	120	127
Blue clay	127	135
Coarse black sand	135	152
Brown clay	152	156

Work started 4-15 1963 Completed 5-10 1963
Date well drilling machine moved off of well 5-10 1963

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider
(Person, firm or corporation) (Type or print)
Address Star Rt., Box 97, St. Paul, Oregon
Drilling Machine Operator's License No. 212

[Signed] _____ (Water Well Contractor)
Contractor's License No. 387 Date 5-10 1963