

MARI. 2395

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 5/2W-11

State Permit No.

(1) OWNER:

Name Woodburn Drag Strip Address Woodburn, Oregon

(2) LOCATION OF WELL:

County Marian Driller's well number 1/4 Section 11 T. 5S R. 2W W.M. Bearing and distance from section or subdivision corner

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? Yes No If yes, by whom? driller. Yield: 25 gal./min. with 43 ft. drawdown after 4 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Depth drilled 120 ft. Depth of completed well 120 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Surface, Brown sandy clay, Blue clay, Blue sandy clay, Broken sand and small gravel, Blue clay.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon. If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded 6" Diam. from 0 ft. to 120 ft. Gage 1/4"

(7) PERFORATIONS:

Perforated? Yes No. Type of perforator used Millknife. Size of perforations 3/8 in. by 1 1/2 in. 12 perforations from 97'6" ft. to 98'6" ft.

(8) SCREENS:

Well screen installed? Yes No. Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Mud. Depth of seal 25 ft. Was a packer used? No. Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? No Depth. Was a drive shoe used? No. Was well gravel packed? No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 4/22/64 Artesian pressure lbs. per square inch

(13) PUMP:

Manufacturer's Name Rapidayton Type: Submersible H.P. 3/4

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller (Person, firm or corporation) Address P.O. Box 42 Hubbard, Oregon Drilling Machine Operator's License No. 277 [Signed] John T. Miller (Water Well Contractor) Contractor's License No. 26 Date April 25, 1964