

RECEIVED
 JAN - 5 1962

Handwritten: MAR 24/62
 61907

Handwritten: 5/2W-12

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
GENERAL DIVISION STATE OF OREGON

State Well No. _____
 State Permit No. _____

(1) OWNER:

Name Senior Citizens of the West, Inc.
 Address Woodburn, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
 1/4 1/4 Section 12 T. 5S R. 2W W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 16" Diam. from 0 ft. to 152' ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used Millknife
 SIZE of perforations 1/4 in. by 2 in.
 210 perforations from 127 ft. to 134 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? 40 ft.
 Material used in seal— Bentonite Mud
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 25 ft. below land surface Date 11/27/61
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: SENIOR ESTATES, INC.
 [Signed] J. Hankal, VP. Date December 5, 1961
 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 600 gal./min. with 70 ft. drawdown after 8 hrs.
 " " " " " " " "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 16 inches.
 Depth drilled 152 ft. Depth of completed well 152 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface	0	3
Brown sandy clay	3	31
Blue sandy clay	31	77
Blue clay	77	83
Sand	83	90
Blue sandy clay	90	118
Sand	118	122
Gravel and sand	122	135
Brown sandy clay	135	145
Blue clay	145	152

Work started November 15, 1961 Completed November 27, 1961

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
 (Person, firm, or corporation) (Type or print)
 Address P O Box 42 Hubbard, Oregon

Driller's well number _____

[Signed] _____
 (Well Driller)

License No. 277 Date December 5, 1961