

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

MAR 28 1963 WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 5/2W-13

State Permit No.

for additional information refer to log for Keith J. MARI... 2438 received 3/31/81 G-2518

(1) OWNER:

Name PAUL WILLARD
Address ROUTE 1 BOX 76
GERVAIS ORE

(2) LOCATION OF WELL:

County MARION Driller's well number
1/4 Section 13 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner
S.W. 1/4

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 173 ft. Gage 4 1/2"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used HILLS TYPE
Size of perforations 3/8 in. by 3" in.
322 perforations from 130 ft. to 146 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 55' ft. Was a packer used? yes
Diameter of well bore to bottom of seal 16" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? SANDY Depth of strata 85' TO 125'
Method of sealing strata off CASE.

(10) WATER LEVELS:

Static level B' ft. below land surface Date 3-21-63
Artesian pressure _____ lbs per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level SETTLER SUPPLY
Was a pump test made? Yes No If yes, by whom? SETTLER SUPPLY
Yield: 500 gal./min. with 45 ft. drawdown after 1 hrs.
" 600 " 58 " 1 "
" 725 " 68 " 1 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 55° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 173' ft. Depth of completed well 173' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	30
CLAY BLUE COLOR SANDY	30	55
CLAY BLUE - STICKY	55	85
SAND - FINE - BLUE	85	125
CONGLOMERATE 2"	125	131
GRAVEL + SAND 2"	131	146
CLAY BLUE - SANDY	146	170
CLAY BLUE STICKY	170	173

Work started 3-14 19 63 Completed 3-21 19 63
Date well drilling machine moved off of well 3-22 19 63

(13) PUMP:

Manufacturer's Name _____
Type: TURBINE H.P. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. N.E. SALEM, ORE

Drilling Machine Operator's License No. 187

[Signed] P. J. Sneed
(Water Well Contractor)

Contractor's License No. 6 Date 3-22, 19 63