NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

 WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310
 within 30 days from the date

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write shove this line)

10 AR State Well No. 55/2w-17

State Permit No. 6-9628

of well completion. (Do not write a	pove ture lure)	
(1) OWNER:	(10) LOCATION OF WELL:	
Name BRENTFORD MILLER	County MARTON Driller's well nu	mber 80-7-R
Address 4637 KARTHALER RD.		R. 2W W.M.
GERVAIS, OREGON 97026	Bearing and distance from section or subdivision	
(2) TYPE OF WORK (check):		
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	eII.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 9	_
Tatry ☑ Driven ☐ Domestic ☐ Industrial ☐ Municipal ☐	Static level 25 ft. below land st	urface. Date 4-20-80
Dug	Artesian pressure lbs. per square	
(5) CASING INSTALLED: Threaded Welded	(40) 77777 7 0 0	
10 Diam. from	1	elow casing0
" Diam. fromft. toft. Gage	Depth drilled 140 ft. Depth of comple	
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each strature	nd structure of materials;
	with at least one entry for each change of format	ion. Report each change in
(6) PERFORATIONS: Perforated? Z Yes No.	position of Static Water Level and indicate princ	ipal water-bearing strata.
Type of perforator used TORCH	MATERIAL	From To SWL
Size of perforations in. by 4 in.	TOP SOIL	0 2
perforations from	BROWN CLAY	2 32
148perforations from120ft. to140ft.	BROWN SAND & CLAY	32 47 47 54
perforations fromft. toft.	BLUE CLAY GREY SAND	54 76
(7) SCREENS: Well screen installed? Yes Kno	BLACK SAND	76 108
Manufacturer's Name	SAND & GRAVEL	108 140 25
Type Model No.	the second secon	
Diam. Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.	RECEIVED	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	MAY 2 3 1980	
a pump test made? Yes No If yes, by whom?		
Yield: gal./min. with ft. drawdown after hrs.	WATER RESOURCES DEPT	
AIR TEST 300 " 65 " 3 "	SALEM, OREGON	
n n	. ÷ 3 4 - 15	
An And was all the second and the se		
Temperature of water 52 Depth artesian flow encountered ft.	Work started 4-19 1980 Completed	1 4-25 19 80
(9) CONSTRUCTION:	Date well drilling machine moved off of well	4-26 ¹⁹ 80
Well seal-Material used CEMENT	Drilling Machine Operator's Certification:	
Well sealed from land surface to	This well was constructed under my Materials used and information reported	direct supervision.
Diameter of well bore to bottom of seal	best knowledge and belief.	bove are true to my
Diameter of well bore below seal	[Signed] (Drilling Machine Operator)	Date 4 5-24 ₁₉ 80
Number of sacks of cement used in well seal 12 sacks	Drilling Machine Operator's License No	070
PRESSURE GROUTED FROM BOTTOM		J-4-0
	Water Well Contractor's Certification:	
7	This well was drilled under my jurisdic	tion and this report is
Was a drive shoe used? 🕱 Yes 🗌 No Plug Size: location ft.	true to the best of my knowledge and believed Name FLORES WELL DRILLING	ì.
Did any strata contain unusable water? Tes XNo	(Person, firm or corporation)	(Type or print)
Type of water? depth d strata	Address 12143 RIVER RD. N.E., GE	RVAIS 97026
Method of sealing strata off	[Signed] Thomas Flor	ed
Was well gravel packed? Yes No Size of gravel:	(Water Well Contrac	ctor)
Gravel placed from ft.	Contractor's License No. 590 Date	5-24 19 80

(USE ADDITIONAL SHEETS IF NECESSAR