

RECEIVED

MAR 25 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT STATE OF OREGON

State Well No. 5/2w-18

State Permit No.

(1) OWNER:

Name: Glenn Larsen
Address: 4426 Marshall, Oregon

(2) LOCATION OF WELL:

County: Marion Driller's well number:
Section: 18 T. 5S. R. 2W W. 2
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [] Deepening [x] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 60 ft. to 80 ft. Gage 250
Threaded [] Welded [x]

(7) PERFORATIONS:

Perforated? [x] Yes [] No
Type of perforator used: Miller
Size of perforations: 3/8 in. by 3/4 in.
48 perforations from 70 ft. to 78 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name:
Type: Model No.
Slot size: Set from ft. to ft.
Diam. Slot size: Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal:
Depth of seal ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? [] Yes [x] No Depth:
Was a drive shoe used? [] Yes [] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 6 inches ft. below land surface Date Aug 1, 1966
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? [x] Yes [] No If yes, by whom? Larsen
Yield: 300 gal./min. with 70 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well below casing:
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries: Black Sand (60-70), Gravel - water bearing (70-80).

Work started July 27 1966 Completed Aug 1 1966
Date well drilling machine moved off of well Aug 1 1966

(13) PUMP:

Manufacturer's Name:
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: J.F. Terrell (Person, firm or corporation)
Address: Rt. 1, Box 57, Exton, Oregon
Drilling Machine Operator's License No. 179
[Signed] Mrs. June D. Terrell (Water Well Contractor)
Contractor's License No. 460 Date Aug 2, 1966