

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
MAY 19 1964
STATE ENGINEER
SALEM, OREGON

MAR 25 27

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

State Well No. 5/2W-18R(1) 19

State Permit No.

(1) OWNER:

Name Norman Nibler
Address Rt. 1, Box 430, Woodburn, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section 19 T. 5 R. 2 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

16" Diam. from 0 ft. to 20 ft. Gage 1/4
10" Diam. from 0 ft. to 95 ft. Gage 1/4

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used mill knife
Size of perforations 1/4 in. by slots zig zag
140 perforations from 80 ft. to 92 ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No size of gravel: 3/4 minus.
Gravel placed from top ft. to bottom ft. 95
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level seepage ft. below land surface Date 5-11-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom J. T. Miller
Yield: 200 gal./min. with 37 ft. drawdown after hrs.
" 400 " 70 " 6, overall "

Baller test gal./min. with ft. drawdown after hrs.
Artesian flow seep's UVEP m. Date

Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 95 ft. Depth of completed well 95 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
surface	0	3
clay, blue	3-	50
sand, some water, brown	50	58
fine sandy clay, blue	58	78
large gravel, water	78	83
gravel, water, black	83	95

Work started 5-11-64 19 64 Completed 5-11-1964
Date well drilling machine moved off of well 5-11-1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. T. Miller (Person, Firm or Corporation) (Type or print)
Address BOX, 175, Aurora, Ore

Drilling Machine Operator's License No. 191

[Signed] J. T. Miller (Water Well Contractor)

Contractor's License No. 7 Date 5-11-1964