

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 5/2w-19bdb

State Permit No. _____

STATE ENGINEER

G 5091

(1) OWNER:

Name HOMER ZIELINSKI
Address 741 BOX 69 GERVAS ORE. 97026

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 166 ft. Gage 4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used MILLS
Size of perforations 3/8" in. by 2 1/2" in.
130 perforations from 108 ft. to 110 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 9' ft. below land surface Date 2-9-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
Yield 30 gal./min. with 40' ft. drawdown after 1 hrs.
550 " 43 " 1 1/2 "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 51° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used MURDERED CLAY
Depth of seal 55' ft.
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? SANDY depth of strata 100' to 81'6"
Method of sealing strata off CASED
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County MARION Driller's well number _____
1/4 1/4 Section 19 T. 55 R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 166' ft. Depth of completed well 166' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW COLOR	2	21	
CLAY BLUE - SILTY	21	45	
CLAY BLUE SANDY-FINE	45	54	
CLAY BLUE STICKY	54	60	
SAND BLACK FINE	60	81'6"	
GRAVEL & SAND 1" 75% SAND	81'6"	98	
CONGLOMERATE	98	106	
GRAVEL & SAND 1"	106	108	
GRAVEL 1"	108	113	
GRAVEL COARSE 3"	113	115	
CLAY BLUE STICKY	115	117	
CLAY SANDY	117	123	
SAND-PACKED-FINE	123	141	
CLAY BLUE SOFT-	141	150	
CLAY SANDY	150	159	
CLAY BLUE STICKY	159	161	
CLAY GRAY COLOR	161	166	

Work started 1-26- 1968 Completed 2-9- 1968
Date well drilling machine moved off of well 2-9- 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] H. F. Sneed Date 2-10- 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD SALEM ORE
97303

[Signed] H. F. Sneed
(Water Well Contractor)

Contractor's License No. 6 Date 2-10- 1968