

MAR 25 1966
RECEIVED
 DEC 29 1966

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)
 G-3773

State Well No. 5/2W-20F
 State Permit No. _____

(1) OWNER:
 Name ERNEST + IRENE ANDRES
 Address RT. 1 BOX 434 WOOD BURN ORE.

STATE ENGINEER

(11) WELL TESTS:
 Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
 Yield: 600 gal./min. with 82 ft. drawdown after 1 hrs.
 " 500 " " 59 " " 1 "
 " 400 " " 47 " " 1 "
 " 300 " " 31 " " 1 "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(2) LOCATION OF WELL:
 County MARION Driller's well number _____
 1/4 Section 20 T. 5S R. 2W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG: Diameter of well below casing 12"
 Depth drilled 159' ft. Depth of completed well 159' ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

MATERIAL	FROM	TO
TOPSOIL	0	3
CLAY YELLOW COLOR	3	32
CLAY BLUE-COLOR- SILTY	32	60
CLAY BLUE STICKY	60	90
SAND-BLACK FINE-MUDDY	90	103
SAND + PEBBLES- 90% SAND	103	113'6"
GRAVEL + SAND MEDIUM	113'6"	116
CLAY BLUE SANDY	116	125'6"
GRAVEL + SAND 1"	125'6"	131'6"
CONGLOMERATE	131'6"	142'6"
GRAVEL + SAND- 1"	142'6"	144
CONGLOMERATE	144	148
GRAVEL 3"	148	151
CONGLOMERATE	151	158
CLAY BLUE STICKY	158	159

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0 ft. to 160 ft. Gage 1/4"
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used MILLS
 Size of perforations 3/8 in. by 3" in.
536 perforations from 137 ft. to 156 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ in. Slot size _____ Set from _____ ft. to _____ ft.
 _____ in. Slot size _____ Set from _____ ft. to _____ ft.

Work started 12-12-1966 Completed 12-22-1966
 Date well drilling machine moved off of well 12-26-1966

(9) CONSTRUCTION:
 Well seal—Material used in seal BENTONITE
 Depth of seal 9.0' ft. Was a packer used? yes
 Diameter of well bore to bottom of seal 15 1/2" in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? SANDY depth of strata 103 TO 113'6"
125' TO 131'
 Method of sealing strata off _____

(13) PUMP:
 Manufacturer's Name _____
 Type: _____ H.P.

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME J.A. SNEED & SONS
 (Person, firm or corporation) (Type or print)
 Address 3910 SILVERTON RD. SALEM, ORE.
 Drilling Machine Operator's License No. 187
 [Signed] J.A. Sneed
 (Water Well Contractor)
 Contractor's License No. 6 Date 12-27-1966

(10) WATER LEVELS:
 Static level 18'6" ft. below land surface Date 12-22-66
 Artesian pressure _____ lbs. per square inch Date _____