

WATER WELL REPORT
STATE OF OREGON

State Well No.

State Permit No. 1878

MARI. 259

(1) OWNER:

Name TED WELTY
Address 12616 S.W. 65th ST.
PORTLAND 19 ORE

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
NW 1/4 SE 1/4 Section 3 T. 45 R. 1W W.M.
Bearing and distance from section or subdivision corner
2640 feet West & 3450 feet South from
NE corner Section 3, T45 R1W

(3) TYPE OF WORK (check): OLD WELL
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" " Diam. from 1 ft. to 149 ft. Gage 4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
None perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name
Type Model No.
in. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? Yes No Size of gravel: 10" +
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 10" +
Material used in seal— PUMP
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off BACK FILL

(10) WATER LEVELS:
Static level 71 ft. below land surface Date 1951
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Date , 1951
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level SETTLER

Was a pump test made? Yes No If yes, by whom? SUPPLY
Yield: 350 gal./min. with 40 ft. drawdown after 2 hrs.
" " " "
" " " "
" " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 8" 1-D inches.
Depth drilled 149 ft. Depth of completed well 149 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	2	2
CLAY YELLOW COLOR	32	34
CLAY BLUE COLOR-SANDY	41	75
SAND BROWN FINE GRAIN	20	95
CLAY BLUE COLOR SANDY	20	115
SAND BROWN FINE GRAIN	12	127
CLAY BLUE STICKY	21	148
WATER GRAVEL #3"	1	149
BLUE CLAY		

THIS WELL HEAVILY BAILED TO REMOVE ALL SMALL GRAVELS + SAND AT BOTTOM THEN TURBINE PUMPED

Work started 1957 Completed 1951

(13) PUMP: Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED + SONS
(Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST. SALEM O.

Driller's well number
[Signed] J. A. Sneed
(Well Driller)
License No. 6 Date 4-19-1958