

MARION 26/2

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 5/24-22
State Permit No. _____

(1) OWNER:
Name LILLIAN A. TEDROW
Address RT. I BOX 229 GERVAIS, OREGON.

(2) LOCATION OF WELL:
County MARION Driller's well number 843
1/4 Section 22 T. 5 S. R. 2 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
_____ " Diam. from _____ ft. to _____ ft. Gage _____
8 " Diam. from TOP ft. to 141 ft. Gage _____
_____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used MILLS
Size of perforations in. by in.
160 perforations from _____ ft. to _____ ft.
118 perforations from _____ ft. to 138 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUTTLE CLAY
Depth of seal 18 ft. Was a packer used? _____
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 14 ft. below land surface Date 7/2/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 250 gal./min. with 135 ft. drawdown after 2 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 141 ft. Depth of completed well 141 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	5
CLAY	5	30
SAND	30	40
CLAY	40	65
SAND	65	75
CLAY	75	80
SAND	80	115
GRAVEL	115	141

SET PUMP AT 135 FT.

Work started JUNE 22 19 63 Completed JULY 2 19 63
Date well drilling machine moved off of well JULY 2 19 63

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON.

Drilling Machine Operator's License No. 141
[Signed] Emil O. Baier
(Water Well Contractor)
Contractor's License No. _____