

MARION 2625

RECEIVED
MAR 10 1967

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT STATE ENGINEER OREGON
STATE OF OREGON
(Please type or print)

State Well No. 5/2w-23
State Permit No.

(1) OWNER:
Name AL BRINLEE
Address RT. 1 BOX 337 A
GERVAIS, OREGON 97206

(2) LOCATION OF WELL:
County MARION Driller's well number I200
1/4 1/4 Section 23 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): (5) TYPE OF WELL:
Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(6) CASING INSTALLED:
6" Diam. from TOP ft. to I32 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level I9 ft. below land surface Date 3/13/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 30 gal./min. with I6 ft. drawdown after I hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing
Depth drilled I32 ft. Depth of completed well I32 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
YELLOW CLAY	2	28
BLUE CLAY	28	75
BLACK SAND	75	95
BLUE CLAY	95	110
BLACK SAND	110	125
GRAVEL	125	132

Work started MAR. 3 1967 Completed MAR. 13 1967
Date well drilling machine moved off of well MAR. 13 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.
Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLAMETTE DRILLING CO (Type or print)
(Person, firm or corporation)
Address RT. 2 BOX 276 SALEM, OREGON 97303
Drilling Machine Operator's License No. I4I
[Signed] Emil O. Beier (Water Well Contractor)
Contractor's License No. 2 Date MAR. 13 1967