

NOTICE TO WATER WELL CONTRACTOR
The original and file copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
JUL 11 1967

WATER WELL REPORT

STATE ENGINEER STATE OF OREGON

(Please type or print)
(Do not write above this line)

2628
MARI...
6-6177

23 cda

5/2w 26D

State Well No.

State Permit No.

(1) OWNER:

Name JENSEN BROS
Address RT 2. SILVERTON, OREG

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
24" Diam. from 0 ft. to 20 ft. Gage 1.250
12" Diam. from 1 ft. to 146 ft. Gage 1.250

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used TORCH
Size of perforations 1/8 in. by 12 in.
420 perforations from 76 ft. to 146 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Water level 25 ft. below land surface Date 6/21
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
550 gal./min. with 50 ft. drawdown after 3 hrs.
450 " " 48 " " 2 "
350 " " 44 " " 1 "
Pump test 550 gal./min. with 30 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 28 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? dept of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: 3/8
Gravel placed from 0 ft. to 146 ft.

(11) LOCATION OF WELL:

County MARION Driller's well number
NW 1/4 NW 1/4 Section 26 T. 55 R. 2 W W.M.

Bearing and distance from section or subdivision corner
1100 FT E OF SW COR SEC 23
RIGHT ON SEC LINE 23-26
T55 R 2 W
2 1/2" SURFACE

(12) WELL LOG:

Diameter of well below casing 22
Depth drilled 146 ft. Depth of completed well 146 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	1 1/2	
CLAY BRN	1 1/2	21	
CLAY SANDY GREY	21	50	
SAND FINE BRN	50	69	
CLAY BRN	69	77	
MED SAND BLK W.B.	77	97	
CLAY GREY	97	107	
CLAY GRITTY "	107	120	
COURSE SAND & GRAVEL W.B.	120	139	
COURSE GRAVEL & CLAY	139	146	

Work started 6/13 1967 Completed 6/21 1967
Date well drilling machine moved off of well 6/21 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C.E. Stadel Date 7/10, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADEL & SONS
(Person, firm or corporation) (Type or print)

Address RT 3 BOX 169 SILVERTON

[Signed] Gaul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 7/10, 1967