

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON APR 28 1975

State Well No. 55/2w-24

STATE ENGINEER
SALEM, OREGON

State Permit No.

(Do not write above this line)

(1) OWNER:

Name Roderick Olson
Address 13500 SW Hazel
Beaverton Ore 97005

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 212 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Star 4 Way
Size of perforations 3/8 in. by 1 1/2 in.
430 perforations from 130 ft. to 140 ft.
430 perforations from 195 ft. to 205 ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 425 gal./min. with 66 ft. drawdown after 4 1/2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 36 ft.
Diameter of well bore to bottom of seal 15.5 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal 1/2 sacks
Brand name of bentonite Eastern Oregon
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plug Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section 24 T.5 S R.2 W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 127 ft.
Static level 19 ft. below land surface. Date 3-1-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 115 ft. Depth of completed well 112 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
Brown City Clay	2	18	
Brown Clay	18	28	
Blue Clay	28	76	
Fine Black Sand	76	94	
Black Clay	94	107	
Dark Blue Sand (Fine)	107	113	
Blue Clay (Dark)	113	127	
Gravel	127	140	
Light Green Clay	140	168	
Blue Clay	168	172	
Black Silt	172	180	
Cement Gravel			JH
Sand Gravel	194	205	
Dark Blue Clay	205	215	

Work started 3-5 1975 Completed 4-10 1975
Date well drilling machine moved off of well 4-11 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John W Beck Date 4-11, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. H37

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name J.W. Beck Well Drilling
(Person, firm or corporation) (Type or print)
Address 24137 S. Skyline Dr Corvallis
[Signed] John W Beck
(Water Well Contractor)
Contractor's License No. H49 Date 4-11, 1975