

MAR 26 1967

RECEIVED JUN 6 1967

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT STATE ENGINEER STATE OF OREGON (Please type or print) G-3974

State Well No. 5/2w-24G

State Permit No.

(1) OWNER:

Name D. L. Seely
Address 1940 Boons Ferry Rd.
Woodburn, Oregon 97071

(2) LOCATION OF WELL:

County Marion Driller's well number 1217
1/4 Section 19 & 24 T. 5 R. 2& 1 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]
Rotary [ ] Cable [X] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded [ ] Welded [X]
10" Diam. from top ft. to 230 ft. Gage 250

(7) PERFORATIONS:

Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
280 perforations from 129 ft. to 155 ft.
80 perforations from 218 ft. to 223 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to
Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & Puddle Clay
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [ ] Yes [ ] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [ ] Yes [ ] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 25 ft. below land surface Date 5/26/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? Driller
Yield: 500 gal./min. with 45 ft. drawdown after 8 hrs.
400 " " 35 " 8 "
300 " " 20 " 8 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Plugged 5 feet
Diameter of well below casing
Depth drilled 230 ft. Depth of completed well 225 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top dirt, Yellow clay, Sandy yellow clay, Blue sandy shale, Black sand shale, Black sand muddy, Blue Shale, Blue sandy shale, Black sandy shale, Black sand and gravel, Black sand and pea gravel, Black sand gravel & shale, Black sandy shale, Black Sand, Hard black shale, Black sand and gravel, Muddy black sand.

Work started April 26 19 67 Completed 5/26/67 19
Date well drilling machine moved off of well 5/26/67 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
Address Rt. 2 Box 276, Salem, Oregon 97303
Drilling Machine Operator's License No. 74
[Signed] Emil O. Beier (Water Well Contractor)
Contractor's License No. 2 Date 5/29/67 19