WATER WELL REPORT STATE OF OREGON

RECEIVEU

OCT 4 1982

1) Ct_t_	117-11 NT-	55/2W-25ab
1	State	well no.	

State Permit No.

WATER RESOURCES DEPT.

SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Oregon Rootstock INC.	County Marion Driller's well	number 2447	
Address 10906 Monitor - McKee Rd. N.E.	NW 4 NE 4 Section 25 T. 5S	R. 2W	W.M.
City Woodburn, Oregon 97071 State	Tax Lot # Lot Blk	Subdivision	
(2) TYPE OF WORK (check):	Address at well location: 13367 Portland	Rd. N.E.	
New Well X Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
	Depth at which water was first found 74		ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 39 ft. below la	and surface. Date 9,	/14/82
Rotary Air 🟋 Driven 🗆 Domestic 💥 Industrial 🗆 Municipal 🗆	Artesian pressure lbs. per square inch. Date		
Rotary Mud	(12) WELL LOG: Diameter of well below casing		
(E) CACING INCOMALLED V	Depth drilled 167 ft. Depth of completed well 167 ft.		
(5) CASING INSTALLED: Steel X Plastic Threaded Welded X	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level		
8 "Diam from +1 ft. to 167 ft. Gauge .250			
"Diam. from ft. to ft. Gauge	and indicate principal water-bearing strata.	osition of Static Wa	ter Level
LINER INSTALLED:	MATERIAL	From To	SWL
ft. Gauge	Topsoil	0 2	
(a) DEDECT ATTAIN	Brown Clay	2 23	
(6) PERFORATIONS: Perforated? ¾ Yes □ No Type of perforator used Mills Knife	Gray Clay	23 73	
Size of perforations $5/16/$ in. by $2\frac{1}{2}$ in.	Black Sand	73 79	
160 perforations from 125 ft. to 140 ft.	Sandy Black Sand and Gravel	79 81	
	Black Sand	81 107	
perforations from ft. to ft.	Sandy Black Sand and Gravel	107 120	
perforations from ft. to ft.	Black Sand and Gravel	120 146	
(7) SCREENS: Well screen installed? ☐ Yes 💢 No	Black Sand and Wood	146 163	
Manufacturer's Name	Sticky Blue Clay	163 167	
Type			
Diam. Slot Size Set from ft. to ft.			***************************************
Diam. Slot Size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? ☐ Yes 🏋 No If yes, by whom?			
gal./min. with ft. drawdown after hrs.			
11 " " "		 	
Air test 300+ gal./min. with drill stem at 124 ft. 2 hrs.			
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 9/10/82 19 Complete	ed 9/14/82	
(9) CONSTRUCTION: Special standards: Yes 🔯 No □	Work started 9/10/82 19 Complete Date well drilling machine moved off of well	9/14/82	19 19
Well seal—Material used 8 mesh dry bentonite		3/14/02	19
Well sealed from land surface to 19 ft.	Drilling Machine Operator's Certification:		
Diameter of well bore to bottom of sealin.	This well was constructed under my direct so and information reported above are true to my bo	ipervision. Materi est knowledge and	als used
Diameter of well bore below seal8 in.	[Signed] Dall A. B. L. S. Commission of the Comm		
Number of sacks of cement used in well seal			
How was cement grout placed? 575 1bs. of bentonite used	Drilling Machine Operator's License No. 752		
to fill annulus after placement of first joint	Water Well Contractor's Certification:		
of casing	This well was drilled under my jurisdiction and this report is true to		
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.		
Was a drive shoe used? Yes No Plugs Size: location ft.	Name Willamette Drilling Co. (Person, firm or corporation) (Type or print)		
Did any strata contain unusable water? \(\times \)XNo	Address7365O. Neil. RdN. ESal	.oR97	3.0.3
Type of Water? depth distrata			
Method of sealing strata off	(Water Well Contracto	or)	•••••
Was well gravel packed? ☐ Yes 🛛 No Size of gravel:	Contractor's License No 561 Date		, 19
Gravel placed from ft. to ft.			