| STATE ENGINEER Salem, Oregon WAR\ Well Reco | state well no. 5/2W-25F COUNTYMARTON |
|-----------------------------------------------------------------------------------------|-----------------------------------------|
| Wi A. | APPLICATION NO. CR-2354 |
| OWNER: Philip V. Berning MAIL ADDI | ING RESS: |
| LOCATION OF WELL: Owner's No STAT | AND E: <u>Gervais, Cregon</u> |
| SE 1/4 NW 1/4 Sec. 25 T. 5 S, R. 2 W, W.M. | |
| Bearing and distance from section or subdivision | |
| corner 5 ch. S. & 4 Ch. E. | |
| | |
| | |
| | |
| Altitude at well | |
| TYPE OF WELL: Drilled Date Constructed1952 | |
| Depth drilled 143 Depth cased 143 | Section |
| CASING RECORD: | |
| 10-inch | |
| and | |
| | |
| FINISH: | |
| Mills perforated starting from bo | ttom to 130 up. |
| AQUIFERS: | |
| Topsoil, silt, shale and sand | |
| WATER LEVEL: 13½-feet | |
| PUMPING EQUIPMENT: Type Jacuzzi Turbine Capacity 150 G.P.M. | H.P5 |
| WELL TESTS: | |
| Drawdown 28 ft. after hours | Pumping 140 G.P.M. |
| Drawdown 73 ft. after hours | |
| USE OF WATER Trigation 48 acres, Temp. SOURCE OF INFORMATION CR-2236 DRILLER or DIGGER | |
| ADDITIONAL DATA: | |
| Log X Water Level Measurements Chemic | cal Analysis Aquifer Test |
| REMARKS: Topsoil & silt & subsoil | 291 |
| Blue Shale | 68 |
| Black sand | 84 |
| Blue gray shale Gravel shale (tight) | 122 |
| Gravel & Sand (water) | 130 143 |
| Still in the same gravel when we for | inished. |

State Printing 89316