

NOTICE TO WATER WELL CONTRACTOR:
The original and first copy
of this report are to be
filed with the

RECEIVED
JUN 29 1967
STATE OF OREGON
STATE ENGINEER
Please type or print
(Do not write above this line)

2681
MAR 1967

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

State Well No. 5/2w-26E
State Permit No. _____

(1) OWNER:

Name R.D. Matheny
Address Rt. 1 Box 22
Aurora, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12 3/4 Diam. from 1+0 ft. to 147 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills
Size of perforations 3/8 in. by 2 1/2 in.
564 perforations from 124 1/2 ft. to 145 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 27 ft. below land surface Date 6/26/67
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stettler
_____ gal./min. with 70 ft. drawdown after 3 hrs.
600 " " 65 " " 1 1/2 "
" 500 " " 56 " " 3/8 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drilling mud & Bentonite
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/4 x 1/4
Gravel placed from 18 ft. to 121 ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 5/2w-26E
1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 147 ft. Depth of completed well 147 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	1	
Yellow clay	1	12	
Yellow silty clay	12	25	
Blue silty clay	25	73	
Fine muddy sand	73	89	
Sticky grey clay	89	119	
Small sand & gravel	119	125	
Very sandy gravel	125	130	
Coarse sand & gravel	130	145	
Gravel with clay	145	147	

Work started 6/13 1967 Completed 6/26/67 19
Date well drilling machine moved off of well 6/26/67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Harry A. Robinson Date 6/27, 1967
(Drilling Machine Operator)
Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)
Address 2214 Front St NE Salem, Ore.
[Signed] Harry A. Robinson
(Water Well Contractor)
Contractor's License No. 22 Date 6/27/67, 19