

MARI... 2684  
G2763

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 5/2w-26H

State Permit No.

(1) OWNER:

Name RALPH DUDA  
Address RT 1 Box 169 GERVAIS OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number  
1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner  
APPROX - 200 FT. WEST & 1750 FT. SOUTH OF N.E. COR. OF SEC. 24 T. 5 S. R. 2 W. OF W.M.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 1' ABOVE to 146 ft. Gage 229  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used MILLS KNIFE  
Size of perforations 3/8 in. by 3 in.  
280 perforations from 125 ft. to 145 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
Depth of seal 20 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 13 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 30 ft. below land surface Date 10/30-63  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? DRILLER  
Yield: 450 gal./min. with 70 ft. drawdown after 5 hrs.  
" 350 " 25 " "  
" 200 " 10 " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 10"  
Depth drilled 155 ft. Depth of completed well 145 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL BROWN	0	3
CLAY BROWN	3	20
CLAY BLUE SANDY	20	80
SAND BLUE FINE	80	97
SAND DIRTY BROWN. FINE	97	114
MED CONGLOMERATE W.B	114	125
LOOSE SAND & GRAVEL W.B	125	147
PACKED SAND & CLAY, GREY	147	155
FILLED OPEN HOLE WITH CRUSHD #3 ROCK TO	147'	
2' FT CEMENT PLUG	147 TO 145	

Work started 10/17 1963 Completed 10/30 1963  
Date well drilling machine moved off of well 10/30 1963

(13) PUMP:

Manufacturer's Name  
Type: H.P. ?

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADEL & SONS (Person, firm or corporation) (Type or print)  
Address RT 3 BOX 169 SILVERTON  
Drilling Machine Operator's License No. 84  
[Signed] Paul R. Stadel (Water Well Contractor)  
Contractor's License No. 296 Date 10/1 1963