

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
NOV 15 1967
STATE OF OREGON

WATER WELL REPORT

(Please type or print)
(Do not write above this line)

2697
MARI.....
6-5899

State Well No. 5/2w-
State Permit No. 2766

(1) OWNER:

Name Ray A. Haslebacker
Address RT #2, Box 481, Salem, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 144 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills
Size of perforations 3/8 in. by 3 1/2 in.
432 perforations from 122 ft. to 134 ft.
perforations from 140 ft. to 143 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Type Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 30 ft. below land surface Date Nov 8/67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Hettler
Yield: 400 gal./min. with 60 ft. drawdown after 2 hrs.
500 " " 90 " " 2 "
" " " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Saddle Clay
Depth of seal 25 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Main Driller's well number 70
1/4 Section 35436 T. 5S R. 2 West, W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing
Depth drilled 144 ft. Depth of completed well 144 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown clay	0	35	
Brown sand	35	40	
Blue clay	40	65	
Grey sand	65	75	50
Blue clay	75	95	
Black sand	95	105	40
Blue clay	105	115	
Black sand	115	120	30
Dravel - water being	120	135	
Caprock Black sand	135	139	
Dravel - water being	139	144	

Work started Oct 24 1967 Completed Nov 13 1967
Date well drilling machine moved off of well Nov 8 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J. F. Terrell Date Nov 13 1967
(Drilling Machine Operator)
Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J. F. Terrell (Type or print)
(Person, firm or corporation)
Address Rt. #1, Box 57, Geddys, Ore.
[Signed] Mr. J. F. Terrell
(Water Well Contractor)
Contractor's License No. 460 Date Nov 13 1967