NOTICE TO WATER WELL CONTRACTOR

The original and first copy of the telephone

are to be filed with the WATER WELL REPORT

WATER RESOURCES DEPARTMENT.

SALEM, OREGON 97310

Within 30 days from the date
of well completiwater RESOURCES

STATE OF OREGON

(Please type or print)

Of well completiwater RESOURCES

Part write above this lines

State Well No. 55/2W-2866 State Permit No. G-8167

SALEM OREGON		
1) OWNER:	(10) LOCATION OF WELL:	
Name Wilbur Leutwyler	County MXM Marion Driller's well number 2127	
Address 3965 Oatfeild Ct.  Milwaukee. Oregon 97222	1/4 1/4 Section 28 T. 5S R. 2W W.M.	
2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner	
New Well Deepening Reconditioning Abandon		
f abandonment, describe material and procedure in Item 12.	AND THE REPORT OF THE PARTY OF	11
	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 70	
Rotary Driven Domestic Industrial Municipal Domestic Industrial Municipal Domestic Industrial Domestic Domestic Domestic Industrial Municipal Domestic Domes	Static level 10 ft. below land su	rface. Date $2/28/78$
Oug 🔲 Bored 🗍 Irrigation 🏋 Test Well 🗍 Other 📋	Artesian pressure lbs. per square	inch. Date
CASING INSTALLED: Threaded   Welded   W	(12) WELL LOG: Diameter of well below casing  Depth drilled 156 ft. Depth of completed well 156 ft.  Formation: Describe color, texture, grain size and structure of materials:	
PERFORATIONS: Perforated? X Yes \( \subseteq \text{No.} \)	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
Type of perforator used Mills Knife Perforator	MATERIAL	From To SWL
Size of perforations 7/16 in. by 2 3/4 in.	Topsoi1	0 1
260 perforations from 133 ft. to 155 ft.	Yellow Clay	1 32
perforations from ft. to ft.	Blue Clay ==	32 70
perforations from ft. to ft.	Black Sand	70 100
(E) CORDING	Black Sand Adn Gravel	100 110
(7) SCREENS: Well screen installed? ☐ Yes 🖔 No	Gray Clay	110 125
Manufacturer's Name	Black Sand And Gravel	125   142   142   155
Diam. Slot size Set from ft. to ft. to ft.	Brown Sand and Gravel	155 156
Diam. Slot size Set from ft. to ft.	Blue Clay	133 130
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? X Yes 🗆 No If yes, by whom? driller		
Vield: 600 gal./min. with 20 ft. drawdown after 6 hrs.		
" " "		
n " " " "		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.	Work started 2/11/78 19 Completed	12/28/78 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	2/28/78 19
Well seal—Material used Portland Cement	Drilling Machine Operator's Certification:	
Well sealed from land surface to	tt. This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.	
Diameter of well bore below sealin.	[Signed] Donald W Months Date 2/28/78 <sub>19</sub>	
Number of sacks of cement used in well sealsacks How was cement grout placed? Poured in from the top		
	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was a drive shoe used? X Yes No Plugs Size: location ft.	Name Willamette Drilling Co.	
Did any strata contain unusable water? 📋 jes 🗓 No	(Person, firm or corporation) (Type or print)	
Type of water? depth of strata	Address 1450 Barnick Rd. NE Salem, Or 97303	
Method of sealing strata off	[Signed] Dear	
Was well gravel packed? Tyes X No Size of gravel:	(Water Well Contractor)	
Gravel placed fromft_toft.	Contractor's License No. 561 Date 2/	28/78 <sub>19</sub>