NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JAN 4 1979 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

MAR 2703

State Well No. 5S/2W-28

State Permit No.

(1) OWNER:
Name L. B. Stevens
Address 5844 Keene Rd. NE
Gervias, Oregon 97026

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

CASING INSTALLED: Threaded [ ] Welded [X]
10" Diam. from top ft. to 204 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? [X] Yes [ ] No.
Type of perforator used Mills Knife
Size of perforations 3/8 in. by 2¼ in.
210 perforations from 134 ft. to 153 ft.
80 perforations from 196 ft. to 203 ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? driller
Yield: 500 gal./min. with 80 ft. drawdown after 9 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? poured in from the top
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number 2181
¼ ¼ Section 28 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 70 ft.
Static level 25 ft. below land surface. Date 9/29/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 204 ft. Depth of completed well 204 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Yellow Clay	1	29	
Blue Clay	29	70	
Black Sand	70	109	
Blue Clay	109	125	
Brown Sand and Gravel	125	149	
Blue Clay	149	165	
Black Sand	165	170	
Blue Clay	170	190	
Black Sand and Gravel	190	204	

Work started 9/5/78 19 Completed 9/29/78 19
Date well drilling machine moved off of well 10/2/78 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ronald W. Morton (Drilling Machine Operator) Date 10/2/78, 19
Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Willamette Drilling Co. (Person, firm or corporation) (Type or print)
Address 1450 Barnick Rd. NE Salem, OR 97303
[Signed] Dallas L. Rois (Water Well Contractor)
Contractor's License No. 561 Date 10/2/78, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119