

NOTICE TO WATER WELL CONTRACTOR:  
The original and first copy  
of this report are to be  
filed with the

**RECEIVED**  
JUL 2 1968

**RECEIVED**  
JUN 27 1968

MARI... 2718

STATE ENGINEER, SALEM, OREGON  
within 30 days from the date  
of well completion.

STATE ENGINEER OF OREGON  
SALEM, OREGON  
(Do not write above this line)

STATE ENGINEER  
SALEM, OREGON

Well No. 5/aw-28dc  
State Permit No. G-6611?

**(1) OWNER:**

Name Larry Brown  
Address Rt #1, Box 167, Astoria, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Cable  Dug   
Driven  Jetted  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 130 ft. Gage 250  
" Diam. from " ft. to " ft. Gage "  
" Diam. from " ft. to " ft. Gage "

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

**(8) WATER LEVEL: Completed well.**

Static level 20 ft. below land surface Date 6/25/68  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?

gal./min. with " ft. drawdown after " hrs.  
" " " " " "  
" " " " " "  
Bailer test 40 gal./min. with 10 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54° Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Reddish Clay  
Depth of seal 25 ft.  
Diameter of well bore to bottom of seal 8 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from " ft. to " ft.

**(11) LOCATION OF WELL:**

County Multnomah Driller's well number  
1/4 1/4 Section 28 T. 5 R. 2 West W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing

Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates

MATERIAL	From	To	SWL
White Clay	0	5	
Brown Clay	5	35	
Brown sand	35	40	
Blue clay	40	65	
Dry sand	65	75	
Bluish sand	75	85	
Blue clay	85	105	
Black sand coarse	105	110	
Brown clay	110	120	
Brown sand	120	125	
Drain - Water being	125	130	

Work started 6/20 1968 Completed 6/25 1968  
Date well drilling machine moved off of well 6/25 1968

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Terrell Date 6/25 1968  
Drilling Machine Operator

Drilling Machine Operator's License No. 179

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. F. Terrell Well Drilling  
(Person, firm or corporation) (Type or print)

Address Rt. #1, Box 57 Corvallis, Ore.

[Signed] Mr. J. F. Terrell  
(Water Well Contractor)

Contractor's License No. 460 Date 6/25 1968