NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON OF 10 within 30 days from the date

WATER WELL REPRET CEIVED

State Well No. 55/2W-080	State Well No.	55/	2W-	-280	
--------------------------	----------------	-----	-----	------	--

of well completion.

STATE OF OREGON MAY 2 8 1975 (Do not write above this lightATE ENGINEERState Permit No.

of wen completion.	SALEM OREGON			
1) OWNER:	(10) LOCATION OF WELL:			
Name James L. Willis	County Marion Driller's well number 75-16-C			
Address Rt. 1, Box 13		0 7:7		
Gervais, Oregon 97026				
2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	n corner		
- · · · · · · · · · · · · · · · · · · ·				
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed we	ell.		
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	73 ft.		
Rotary Driven Domestic Industrial Municipal Cable Detted	Static level 35 ft. below land st	urface. Date 5-19-7		
Oug 🗍 Bored 🖟 Irrigation 🗎 Test Well 🗎 Other 📋	Artesian pressure lbs. per square	e inch. Date		
CASING INSTALLED: Threaded Welded				
CASING INSTALLED: Threaded Welded Welded Language 41 ft. to 118 ft. Gage 250		elow casing 0		
-	Depth drilled 118 ft. Depth of comple	eted well 118 ft.		
	Formation: Describe color, texture, grain size a			
" Dlam, from ft. to ft. Gage	and show thickness and nature of each stratum with at least one entry for each change of format			
PERFORATIONS: Perforated? Yes X No.	position of Static Water Level and indicate prince			
Type of perforator used	MATERIAL	From To SWL		
Size of perforations in. by in.	TOP SOIL	0 2		
perforations from ft. to ft.	BROWN CLAY	2 23		
perforations fromft. toft.	BROWN SANDY CLAY	23 73		
perforations from ft. to ft.	BLACK SAND	73 95 35		
periorations from	GREY CLAY	95 115		
(7) SCREENS: Well screen installed? ☐ Yes ☒ No	GRAVEL	115 118 15		
Manufacturer's Name				
TypeModel No				
Diam Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? F Yes □ No If yes, by whom? []] er				
Yield: 60 gal./min. with 60ft. drawdown after 4 hrs.				
" " "				
n n n				
Artesian flow g.p.m.				
perature of water 52 Depth artesian flow encountered ft.	Work started 5-13 19 75Complete			
(9) CONSTRUCTION:	Date well drilling machine moved off of well	5-23 1975		
Well seal—Material used <u>CEMENT</u>	Drilling Machine Operator's Certification:			
Well sealed from land surface to	This well was constructed under my Materials used and information reported	direct supervision.		
Diameter of well bore to bottom of seal	best knowledge and belief	above are true to my		
Diameter of well bore below seal	[Signed] Nichard L. Wright]	Date <i>May</i> 26, 19 <i>75</i>		
Number of sacks of cement used in well seal sacks	(Drining Machine Operator)	2/0		
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No	1.92		
Brand name of bentonite	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdie	ction and this manage :~		
of waterlbs./100 gals.	true to the best of my knowledge and beli	ef.		
Was a drive shoe used? Yes No Plugs Size: location ft.	Name FLORES WELL DRILLING	! f		
Did any strata contain unusable water?	(Person, firm or corporation)	(Type or print)		
Type of water? depth of strata	Address RT.1, BOX 56, GERVAIS,	OREGON 97026		
Method of sealing strata off	[Signed] Thomas D File	rep		
Was well gravel packed? Yes No Size of gravel:	(Water Well Contra			
Gravel placed fromft. toft.	Contractor's License No590 Date	MAY 2-6 107		