NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

STATE OF OREGON

STATE OF OREGON

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Please type or print)
(Do not write above this line)

State	Well	No.	5	<u> </u>	.w-	29	
State	Pern	nit N	о				

(1) OWNER: SALEM, OREGO	(10) LOCATION OF WELL:				
Name Leo B. Stevens	County Marion Driller's well number 2288				
Address 5844 Keene Rd. N.E.	14 14 Section 29 T. 5S	R. 2W W.M.			
Gervais, Ogegon 97026	Bearing and distance from section or subdivision				
(2) TYPE OF WORK (check):	Bearing and distance from Section of Subdivision	on corner			
New Well Deepening Reconditioning Abandon					
If abandonment, describe material and procedure in Item 12.	(11) THAMBER TRANSPORT OF THE	**			
(2) TYPE OF WELL. (4) PROPOSED USE (about).	(11) WATER LEVEL: Completed w	ell.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 67	ft.			
Rotary Driven Domestic Industrial Municipal	Static level 15 ft. below land s	urface. Date 4/14/80			
☐ Bored ☐ Irrigation 🕅 Test Well ☐ Other ☐	Artesian pressure lbs. per squar	e inch. Date			
(5) CASING INSTALLED: 10 "Diam from top ft to 240 ft Gage .250 "Diam from ft to ft Gage	(12) WELL LOG: Diameter of well below casing				
Type of perforator used Mills Knife	MATERIAL				
Size of perforations 3/8 in. by 2½ in.	Topsoil	From To SWL			
	Yellow Clay	1 28			
perforations from 11, to 11.	Blue Clay	28 67			
140 perforations from 190 ft. to 198 ft. 330 perforations from 220 ft. to 238 ft.	Black Sand	67 105			
perforations from ft. to ft.	Sandy Blue Clay	105 119			
(7) SCREENS: Well screen installed? ☐ Yes [X No	Brown Sand and Gravel	119 140			
Manufacturer's Name	Blue Clay	140 175			
Type	Sandy Blue Clay	175 185			
Diam. Slot size Set from ft. to ft.	Black Sand and Gravel	185 198			
Diam Slot size Set from ft. to ft.	Blue Clay	198 216			
	Cemented Black Sand and Gravel	216 239			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Blue Clay	239 240			
a pump test made? Yes No If yes, by whom? driller					
Yield: 600 gal./min. with 31 ft drawdown after $2\frac{1}{2}$ hrs.					
" " " " "					
<i>"</i>					
Bailer test gal./min. with ft. drawdown after hrs.					
Assesian flow g.p.m.					
Temperature of water Depth artesian flow encountered ft.	Work started 2/14/80 19 Complete	d 4/14/80 19			
(9) CONSTRUCTION:	Date well drilling machine moved off of well	4/15/80 19			
Well seal—Material usedPortland Cement	Drilling Machine Operator's Certification:				
Well sealed from land surface to	This well was constructed under my Materials used and information reported best knowledge and belief.	above are true to my			
Number of sacks of cement used in well seal10½ sacks	[Signed] Donald W. Mortan I	Date 4/13/80, 19			
How was cement grout placed? PRINK Poured thru tremy	Drilling Machine Operator's License No				
pipe	Water Well Contractor's Certification:				
	This well was drilled under my jurisdic	ction and this report is			
Was a drive shoe used? X Yes \(\subseteq No \) Plugs Size: location ft.	true to the best of my knowledge and beli-	ef.			
Did any strata contain unusable water? 🗆 🐮 🔀 No	Name Willamette Drilling Co. (Person, firm or corporation)				
Type of water? depth ostrata	Address 7365 O'Neill Rd. N.E. Sa	1em, Oregon 9730			
Method of sealing strata off	[Signed] Dollar Loces				
Was well gravel packed? ☐ Yes 🏋 No. Size of gravel:	(Water Well Contra	ctor)			
Gravel placed fromft_tof'	Contractor's License No. 561 Date 4	/15/80			
	EETS IF NECESSARY)	10			