

RECEIVED

MARION 2726

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON WATER WELL REPORT

State Well No. 5/2w-29
State Permit No.

(1) OWNER:
Name MARVIN E. & BILLIE WOODS
Address RT. 1 GERVAIS, OREGON

(2) LOCATION OF WELL:
County MARION Driller's well number I008
1/4 Section 29 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]
(5) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:
Threaded [ ] Welded [X]
8" Diam. from TOP ft. to I20 ft. Gage 250

(7) PERFORATIONS:
Perforated? [X] Yes [ ] No
Type of perforator used MILLS
Size of perforations 3/8 in. by 2 in.
I68 perforations from I07 ft. to I20 ft.

(8) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to
Diam. Slot size Set from ft. to

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [ ] Yes [ ] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [ ] Yes [ ] No
Type of water depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level I2 ft. below land surface Date 3/1/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? DRILLER
Yield: 265 gal./min. with 38 ft. drawdown after 6 hrs.
" 200 GAL " 33 " 6 "
" I50 " 23 " 6 "
Pump test I00 gal./min. with I6 ft. drawdown after 6 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:
Diameter of well below casing
Depth drilled I20 ft. Depth of completed well I20 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include TOP SOIL, YELLOW CLAY, YELLOW SANDY SILT, BLUE SHALE, BLACK SAND, BLACK SAND & GRAVEL.

Work started FEB 17 1965 . Completed MAR. 1 1965
Date well drilling machine moved off of well MAR. 1 1965 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
(Person, firm or corporation)
Address RT. 2 BOX 276 SALEM, OREGON
Drilling Machine Operator's License No. 74
[Signed] Emil O. Beiers
(Water Well Contractor)
Contractor's License No. 2 Date MAR. 1 1965, 19