

MARION 2749

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT SEP 22 1966 STATE OF OREGON (Please type or print) G-3942

State Well No. 5/2w-30A State Permit No. G-8139

(1) OWNER:

Name EDGAR SMITH Address RT. 1 BOX 32 GERVAIS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number II77 1/4 Section 30 T. 5S R. 2 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded [] Welded [X]

8" Diam. from TOP ft. to 120ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No

Type of perforator used MILLS Size of perforations 3/8 in. by 2 in. 112 perforations from 108 ft. to 120 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Model No. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 38 ft. below land surface Date 9/20/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER Yield: 250 gal./min. with 52 ft. drawdown after 4 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 120 ft. Depth of completed well 120 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, YELLOW CLAY, SILTY CLAY, BLUE SHALE, BLACK SHALE, BLACK SANDY SHALE, BLACK SAND & GRAVEL, BLACK SAND & GRAVEL & SHALE.

Work started SEPT 14 1966 Completed SEPT. 20 1966 Date well drilling machine moved off of well SEPT 20 1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 74

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date SEPT 20 1966