

2769
MARI....

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED WATER WELL REPORT
MAY 24 1965
STATE OF OREGON
(Please type or print)
STATE ENGINEER

State Well No. 5/2w-31
State Permit No. _____

(1) OWNER: SALEM, OREGON

Name FRED & ALTA VIESKO
Address RT. 1 BOX 105
GERVAIS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I026
1/4 Section 31 T. 5 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded

I2 " Diam. from TOP ft. to I80 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used MILLS
Size of perforations 1/2 in. by 2/4 in.
388 perforations from I04 ft. to I45 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusuable water? Yes No
Type of water? _____ dept of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 5/17/65
Artesian pressure _____ lb per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 600 gal./min. with 40 ft. drawdown after 32 hrs.
" 500 " 30 " 32 "
" 450 " 27 " 32 "
~~300~~ 300 gal./min. with 15 ft. drawdown after 32 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____

Depth drilled I80 ft. Depth of completed well I80 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	5
CLAY	5	25
SAND	25	30
CLAY	30	50
SAND	50	65
CLAY	65	75
SAND	75	80
CLAY	80	90
SAND	90	100
GRAVEL	100	110
SAND & GRAVEL	110	120
GRAVEL	120	146
CLAY	146	170
SAND	170	176
CLAY	176	180

Work started NOV 23 1964 . Completed MAY 17 1965
Date well drilling machine moved off of well MAY 17 1965¹⁹

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
(Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. I79

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date MAY 17 1965 19____