RECEIVED MAR 1967 STATE ENGINEER SALEM, OREGON

MARI 2781

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 5/2w-31 K

State Permit No. G-3849

(1) OWNER:
Name RICHARD D. TERRELL
Address RT # I, BOX 57
GERVAIS, OREGON

(2) LOCATION OF WELL:
County MARION Driller's well number 31
¼ ¼ Section 31 T. 5 S R. 2 WEST W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 110 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used MILLS
Size of perforations 3/8 in. by 3 1/2 in.
100 perforations from 106 ft. to 109 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal PUDDLE CALY
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 18 ft. below land surface Date FEB. 20, 1967
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? STSTTLER'S
Yield: 200 gal./min. with 81 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing
Depth drilled 110 ft. Depth of completed well 110 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	5
BROWN CLAY	5	25
BROWN SAND	25	27
BLUE CLAY	27	55
GREY SAND	55	60
BLUE CLAY	60	75
BLACK SAND	75	85
BROWN CLAY	85	95
BLACK SAND	95	98
GRAVEL	98	110

Application No. G-3849
Permit No.

Work started FEB. 7 19 67 Completed MARCH 15 19 67
Date well drilling machine moved off of well FEB. 20 19 67

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.F. TERRELL (Person, firm or corporation) (Type or print)
Address RT # I, BOX 57 GERVAIS, OREGON
Drilling Machine Operator's License No. 179
[Signed] Mrs Zona Gale Terrell (Water Well Contractor)
Contractor's License No. #460 Date March 15, 1967

(USE ADDITIONAL SHEETS IF NECESSARY)