

#2 WELL ON ROBERT ZEILINSKI PROPERTY.

2789
MAR 1 1964

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 5/2W-32
State Permit No.

(1) OWNER:

Name PAUL WILLARD
Address RT 1 BOX 76
CORVALLIS ORE.

(2) LOCATION OF WELL:

County MARION Driller's well number
NE 1/4 Section 32 T. 5 R. 2 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 163 ft. Gage 4/2 #
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 3/8 in. by 3 in.
612 perforations from 117 ft. to 143 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 65 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 76 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? MUDDY SAND Depth of strata 162'
Method of sealing strata off CEMENTED

(10) WATER LEVELS:

Static level 15' ft. below land surface Date 3-6-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? STEFFLER SUPPLY
Yield: 700 gal./min. with 75 ft. drawdown after 1 hrs.
" 650 " 62 " "
" 550 " 53 " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing PLUGGED
Depth drilled 163' ft. Depth of completed well 163' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	1
CLAY YELLOW COLOR	1	30
CLAY BLUE STICKY	30	76
SAND FINE. BLACK	76	97
CONGLOMERATE	97	102
CLAY BLUE - STICKY	102	110
CONGLOMERATE	110	116
GRAVEL 3" - W.B.	116	117'6"
CONGLOMERATE W.B.	117'6"	124
GRAVEL 3" -	124	126
CONGLOMERATE	126	143
CLAY BLUE STICKY	143	152
CONGLOMERATE W.B.	152	162
SAND & CLAY FINE. W.B.	162	163

Work started 2-24 1964. Completed 3-7 1964
Date well drilling machine moved off of well 3-7 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. NE SALEM ORE.

Drilling Machine Operator's License No. 187

[Signed] J.A. Sneed.
(Water Well Contractor)

Contractor's License No. 6 Date 3-9-1964