

1 WELL ON ROBERT ZELINSKI PROPERTY

2798
MARI.....

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 5/2W-32 L
State Permit No.

(1) OWNER: LEASER
Name PAUL WILLARD
Address RT 1 BOX 76
GERVAIS ORE

(2) LOCATION OF WELL:
County MARION Driller's well number
NE 1/4 of SW 1/4 Section 32 T. 5 R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
12" Diam. from 0 ft. to 155 ft. Gage 4 1/2 #
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Type of perforator used MILLS TYPE
Size of perforations 3/8 in. by 2 1/2 in.
60 perforations from 100' ft. to 103' ft.
672 perforations from 113' ft. to 151' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal BENTONITE PACKER
Depth of seal 60' ft. Was a packer used? YES
Diameter of well bore to bottom of seal 16" in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water SANDY Depth of strata 74' TO 95'
Method of sealing strata off CASED & PACKER USED.

(10) WATER LEVELS:
Static level 20' ft. below land surface Date 12-18-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
Yield: 1000 gal./min. with 35 ft. drawdown after 1 hrs.
" 750 " 31 " 1 "
" 650 " 29 " 1/2 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 12"
Depth drilled 155' ft. Depth of completed well 155' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	1
CLAY YELLOW COLOR	1	60
CLAY BLUE COLOR-SANDY	60	74
SAND-BLACK-FINE-W.B	74	95
SAND & GRAVEL 3"-	95	103
CLAY BROWN SANDY	103	109
CONGLOMERATE-W.B	109	124
GRAVEL & SAND 3"-	124	155'

Work started 12-1-63 Completed 12-18-63
Date well drilling machine moved off of well 12-18-1963

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J.A. SHEED & SONS
(Person, firm or corporation) (Type or print)
Address 3910 SILVERTON RD. N.E. SALEM, ORE.
Drilling Machine Operator's License No. 187
[Signed] J.A. Sheed (Water Well Contractor)
Contractor License No. 6 Date 12-18-1963